

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 1 : DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION

DETAILS OF THE CONTRACTOR	DETAILS OF THE CLIENT	DETAILS OF THE INSTALLATION
Registration No: <u>026620</u> Branch No: _____	Contractor Reference Number (CRN): _____	Occupier: _____
Trading Title: <u>WEBSTER THOMAS ELECTRICAL LTD</u>	Name: <u>St Dunstons OPco Ltd</u>	Address: _____
Address: <u>UNIT 7, CASTLE VIEW BUSINESS ESTATE, GAS HOUSE ROAD, ROCHESTER, KENT</u>	Address: <u>20 St Dunstans Hill, London</u>	Postcode: _____ Tel No: _____
Postcode: <u>ME1 1PH</u> Tel No: <u>01634 818074</u>	Postcode: <u>EC3R 8HL</u> Tel No: _____	Postcode: _____ Tel No: _____

PART 2 : PURPOSE OF THE REPORT

Purpose for which this report is required: (see additional page No. N/A)
 CLIENT REQUEST 5 YEAR CONDITION REPORT

Date(s) when inspection and testing was carried out: (20/01/2019 - 12/01/2019) Records available: (Yes.....) Previous inspection report available: (Yes.....) Previous report date: (03/09/2015)

PART 3 : SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety): (see additional page No. N/A)
 GOOD CONDITION

Estimated age of electrical installation: (5) years Evidence of additions or alterations: (Yes.....) Overall assessment of the installation is: **Satisfactory**

PART 4 : DECLARATION

INSPECTION AND TESTING

I, being the person responsible for the inspection and testing of the electrical installation, particulars of which are described in PART 7, having exercised reasonable skill and care when carrying out the inspection and testing of the existing installation, hereby CERTIFY that the information in this report, including the observations (page 2) and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent of the installation and the limitations on the inspection and testing.

Name (capitals): GARY BARDRICK Signature:  Date: 12/01/2019

REVIEWED BY THE REGISTERED QUALIFIED SUPERVISOR FOR THE APPROVED CONTRACTOR

Name (capitals): OWEN THOMAS Signature:  Date: 07/03/2019

**An unsatisfactory assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified in PART 6, or that Further Investigation (CODE FI) without delay is required.*

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 5 : NEXT INSPECTION

I/We (as indicated on page 1) recommend, subject to the necessary remedial work being taken, this installation should be further inspected and tested after an interval of not more than 5 years*

Give reason for recommendation: INSTALLATION IS OVERAL GOOD CONDITION (see additional page No. N/A)

PART 6 : OBSERVATIONS AND RECOMMENDATIONS FOR ACTIONS TO BE TAKEN

CODES: One of the following Codes, as appropriate, has been allocated to each of the observations made below to indicate to the person(s) responsible for the electrical installation the degree of urgency for remedial action

CODE C1 'Danger Present' Risk of injury. Immediate remedial action required	CODE C2 'Potentially Dangerous' Urgent remedial action required	CODE C3 'Improvement Recommended'	CODE FI 'Further Investigation Required'
---	---	---	--

Referring to the Schedule of Items Inspected (see PART 10), the attached Schedule of Circuit Details and Test Results (see PART 12), and subject to any agreed limitations listed in PART 7:

There are no items adversely affecting electrical safety , OR The following observations and recommendations for action are made:

Item No	Observation(s)	Code	Location Reference
1	Absence of RCD protection for a socket-outlet that is unlikely to supply portable or mobile equipment for use outdoors, does not serve a location containing a bath or shower, and the use of which is otherwise not considered by the inspector to result in potential danger. (Note: Code C2 would apply if the circuit supplied a socket-outlet in a	C3	COMMS ROOM
2	Absence of RCD protection for cables installed at a depth of less than 50 mm from a surface of a wall or partition where the cables do not incorporate an earthed metallic covering, are not enclosed in earthed metalwork, or are not mechanically protected against penetration by nails and the like	C3	VARIOUS LOCATIONS

Additional pages? (N/A) State page numbers: (N/A)

Immediate action required for items: () **Improvement recommended** for items: (1, 2)

Urgent remedial action required for items: () **Further investigation required** for items: ()

*The proposed date for the next inspection should take into consideration any legislative or licensing requirements and the frequency and quality of maintenance that the installation can reasonably be expected to receive during its intended life. The period should be agreed between relevant parties.

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

Original to the person ordering the work

PART 7 : DETAILS AND LIMITATIONS OF THE INSPECTION AND TESTING

The inspection and testing has been carried out in accordance with BS 7671: 2018, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the Client and the Inspector prior to inspection.

Details of the installation covered by this report:

LAND LORD AREA'S

(see additional page No. N/A)

Agreed limitations including the reasons, if any, on the inspection and testing:

CIRCUITS UNABLE TO TRACE

(see additional page No. N/A)

COMMS COMMANDO SOCKETS COULD NOT BE DEAD TESTED DUE TO SYSTEM NOT ALLOWED TO BE TURNED OFF, LIVE TEST ONLY.

NO ACCESS TO PRIMARY PROTECTIVE DEVICE (DONE BY ENQUIRY)

Agreed with (print name):

Extent of sampling: 20% OF THE CIRCUIT ACCESSORIES TESTED UNLESS A DEDICATED CIRCUIT WHICH 100% TESTED

(see additional page No. N/A)

Operational limitations including the reasons:

(see additional page No. N/A)

PART 8 : SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System type and earthing arrangements

TN-C-S: TN-S: TT:

Other (state):

Supply protective device

(BS (EN) 88 Fuse HRC

Type: (gG) Rated current: (600) A

Number and type of live conductors

AC 1-phase, 2-wire: 2-phase, 3-wire:

3-phase, 3-wire: 3-phase, 4-wire:

DC 2-wire: 3-wire: Other: (.....)

Confirmation of supply polarity: (LIM)

Other sources of supply: (as detailed on attached schedule) Page No: (.....)

Nature of supply parameters

Nominal line voltage, U : (400) V

Nominal line voltage to Earth, $U_0^{(1)}$: (230) V

Nominal frequency, $f^{(1)}$: (50) Hz

Prospective fault current, $I_{pf}^{(1)*}$: (3.9) kA

External loop impedance, $Z_e^{(1)*}$: (0.13) Ω

⁽¹⁾ By enquiry, measurement, or by calculation

PART 9 : PARTICULARS OF INSTALLATION REFERRED TO IN THIS CERTIFICATE

Means of Earthing

Distributor's facility: ()

Installation earth electrode: ()

Where an earth electrode is used insert

Type - rod(s), tape, etc: (.....)

Location: (.....)

Electrode resistance to Earth: (.....) Ω

Main protective conductors

Earthing conductor: (material Copper csa 300 mm²)

Connection / continuity verified:

Main protective bonding conductors: (material Copper csa 50 mm²)

Connection / continuity verified:

Main protective bonding connections

Water installation pipes: ()

Gas installation pipes: ()

Structural steel: ()

Oil installation pipes: ()

Lightning protection: ()

Other (state):

Main switch / Switch-fuse / Circuit-breaker / RCD

Type: (BS (EN) BS EN 60947-2

Location: (.....)

No. of poles: (4) Rating / setting of device: (.....) A

Current rating: (630) A Voltage rating: (600) V

Where an RCD is used as the main switch

RCD rated residual operating current, $I_{\Delta n}$: (.....) mA

Measured operating time: (.....) ms Rated time delay: (.....) ms

*Where the installation is supplied by more than one source, the higher or highest values of prospective fault current, I_{pf} , and external earth fault loop impedance, Z_e , must be recorded.

All fields must be completed. Enter either, as appropriate: '✓' if Acceptable condition; 'N/A' if Not applicable; 'LIM' if a Limitation exists; or Code appropriately - CODE 'C1', 'C2', 'C3' or 'FI' (codes to be recorded in PART 6, with additional comments (where appropriate) on attached numbered sheets)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

Original to the person ordering the work

PART 10 : SCHEDULE OF ITEMS INSPECTED

<p>1. External condition of electrical intake equipment (visual inspection only) (If inadequacies are identified with the intake equipment, it is recommended the person ordering the report informs the appropriate authority.)</p> <p>1.1 Service cable: (LIM) 1.2 Service head: (LIM) 1.3 Earthing arrangement: (LIM) 1.4 Meter tails: (LIM) 1.5 Metering equipment: (LIM) 1.6 Isolator (where present): (LIM)</p>	<p>4. Other methods of protection (N/A) Details should be provided on separate sheets: Page No. (.....)</p>	<p>5.24 Single-pole switching or protective devices in line conductors only: (✓)</p>
<p>2. Presence of adequate arrangements for parallel or switched alternative sources</p> <p>2.1 Adequate arrangements where a generating set operates as a switched alternative to the public supply: (LIM) 2.2 Adequate arrangements where generating set operates in parallel with the public supply: (LIM) 2.3 Presence of alternative / additional supply arrangement warning notice(s) at or near equipment, where required: (LIM)</p>	<p>5. Distribution equipment</p> <p>5.1 Adequacy of working space / accessibility of equipment: (✓) 5.2 Security of fixing: (✓) 5.3 Condition of insulation of live parts: (✓) 5.4 Adequacy / security of barriers: (N/A) 5.5 Condition of enclosure(s) in terms of IP rating: (✓) 5.6 Condition of enclosure(s) in terms of fire rating: (✓) 5.7 Enclosure not damaged / deteriorated so as to impair safety: (✓) 5.8 Presence and effectiveness of obstacles: (N/A) 5.9 Presence of main switch(es), linked where required: (✓) 5.10 Operation of main switch(es) (functional check): (✓) 5.11 Correct identification of circuit protective devices: (✓) 5.12 Adequacy of protective devices for prospective fault current: (✓) 5.13 RCD(s) provided for fault protection – includes RCBOs: (N/A) 5.14 RCD(s) provided for additional protection – includes RCBOs: (✓) 5.15 RCD(s) provided for protection against fire – includes RCBOs: (N/A) 5.16 Manual operation of circuit-breakers and RCDs to prove disconnection: (✓) 5.17 Confirmation that integral test button/switch causes RCD(s) to trip when operated (functional check) (✓) 5.18 Presence of RCD six-monthly retest notice at or near equipment, where required: (✓) 5.19 Presence of diagrams, charts or schedules at or near equipment, where required: (✓) 5.20 Presence of non-standard (mixed) cable colour warning notices at or near equipment, where required: (N/A) 5.21 Presence of next inspection recommendation label: (✓) 5.22 All other required labelling provided: (✓) 5.23 Compatibility of protective device(s), base(s) and other components: (✓)</p>	<p>5.25 Protection against mechanical damage where cables enter equipment: (✓) 5.26 Protection against electromagnetic effects where cables enter ferromagnetic enclosures: (✓)</p>
<p>3. Automatic disconnection of supply</p> <p>3.1 Main earthing and bonding arrangements</p> <p>a) Presence and condition of distributor's earthing arrangement: (✓) b) Presence and condition of earth electrode arrangement, if present: (N/A) c) Adequacy of earthing conductor size: (✓) d) Adequacy of earthing conductor connections: (✓) e) Accessibility of earthing conductor connections: (✓) f) Adequacy of main protective bonding conductor size(s): (✓) g) Adequacy of main protective bonding conductor connections: (✓) h) Accessibility of main protective bonding connections: (✓) i) Accessibility and condition of other protective bonding connections: (✓) j) Provision of earthing / bonding labels at all appropriate locations: (✓)</p> <p>3.2 FELV</p> <p>a) Source providing at least simple separation: (N/A) b) Plugs, socket-outlets and the like not interchangeable with those of other systems within the premises: (✓)</p>	<p>6. Distribution / final circuits</p> <p>6.1 Identification of conductors: (✓) 6.2 Cables correctly supported throughout their length: (✓) 6.3 Condition of insulation of live parts: (✓) 6.4 Non-sheathed cables protected by enclosures in conduit, ducting or trunking: (✓) 6.5 Suitability of containment systems for continued use (including flexible conduit): (✓) 6.6 Cables correctly terminated in enclosures (indicate extent of sampling in PART 7 of report): (✓) 6.7 Indication of SPD(s) continued functionality confirmed: (N/A) 6.8 Adequacy of AFDD(s), where specified: (N/A) 6.9 Confirmation that conductor connections, including connections to busbars are correctly located in terminals and are tight and secure: (✓) 6.10 Examination of cables for signs of unacceptable thermal and mechanical damage / deterioration: (✓) 6.11 Adequacy of cables for current-carrying capacity with regard to the type and nature of installation: (✓) 6.12 Adequacy of protective devices; type and rated current for fault protection: (✓) 6.13 Presence and adequacy of circuit protective conductors: (✓) 6.14 Co-ordination between conductors and overload protective devices: (✓) 6.15 Cable installation methods / practices appropriate to the type and nature of installation and external influences: (✓) 6.16 Cables where exposed to direct sunlight, of a suitable type or adequately protected against solar radiation: (✓) 6.17 Cables adequately protected against damage and abrasion: (✓)</p>	

All fields must be completed. Enter either, as appropriate: ' ✓ ' if Acceptable condition; 'N/A' if Not applicable; 'LIM' if a Limitation exists; or Code appropriately - CODE 'C1', 'C2', 'C3' or 'FI' (codes to be recorded in PART 6, with additional comments (where appropriate) on attached numbered sheets)




ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

Original to the person ordering the work

PART 10 : SCHEDULE OF ITEMS INSPECTED

6.18 Provision of additional protection by an RCD not exceeding 30 mA a) For all socket-outlets with a rated current not exceeding 32 A, unless exempt: (C3) b) Supplies for mobile equipment with a rated current not exceeding 32 A for use outdoors: (N/A) c) For cables concealed in walls / partitions at a depth of less than 50 mm: (C3) d) For cables concealed in walls / partitions containing metal parts regardless of depth: (C3) e) Circuits supplying luminaires within domestic (household) premises: (N/A) <i>Note: Older installations designed prior to BS 7671: 2018 may not have been provided with RCDs for additional protection.</i>	6.26 Single-pole switching or protective devices in line conductors only: (✓) 6.27 Adequacy of connections, including cpcs, within accessories and to fixed and stationary equipment: (✓) 7. Isolation and switching 7.1 Isolators a) Presence and condition of appropriate devices: (✓) b) Acceptable location (local / remote): (✓) c) Capable of being secured in the OFF position: (✓) d) Correct operation verified: (✓) e) Clearly identified by position and / or durable markings: (✓) f) Warning label posted in situations where live parts cannot be isolated by the operation of a single device: (N/A) 7.2 Switching off for mechanical maintenance a) Presence and condition of appropriate devices: (✓) b) Acceptable location: (✓) c) Capable of being secured in the OFF position: (✓) d) Correct operation verified: (✓) e) Clearly identified by position and / or durable marking(s): (✓) 7.3 Emergency switching off / stopping a) Presence and condition of appropriate devices: (N/A) b) Readily accessible for operation where danger might occur: (N/A) c) Correct operation verified: (N/A) 7.4 Functional switching a) Presence and condition of appropriate devices: (✓) b) Correct operation (functionality) verified: (✓)	8. Current-using equipment (permanently connected) 8.1 Condition of equipment in terms of IP rating: (✓) 8.2 Equipment does not constitute a fire hazard: (✓) 8.3 Enclosure not damaged / deteriorated so as to impair safety: (✓) 8.4 Suitability for the environment and external influences: (✓) 8.5 Security of fixing: (✓) 8.6 Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire: (N/A) List number and location of luminaires inspected on a separate page: Page No. (.....) 8.7 Recessed luminaires (e.g. downlighters) a) Correct type of lamps fitted: (✓) b) Installed to minimise build-up of heat: (✓) c) No signs of overheating to surrounding building fabric: (✓) d) No signs of overheating to conductors / terminations: (✓) 9. List all special installations or locations covered by this report: () () () () <i>Indicate if the relevant requirements of Part 7 are satisfied and append results of inspection on a separate numbered page.</i> SCHEDULE OF ITEMS INSPECTED BY Name (capitals): GARY BARDRICK Signature:  Date: 12/01/2019
6.19 Provision of fire barriers, sealing arrangements and protection against thermal effects: (✓)		
6.20 Band II cables segregated / separated from Band I cables: (✓)		
6.21 Cables segregated / separated from non-electrical services: (✓)		
6.22 Termination of cables at enclosures (indicate extent of sampling in PART 7 of report) a) Connections under no undue strain: (✓) b) No basic insulation of a conductor, visible outside an enclosure: (✓) c) Connections of live conductors adequately enclosed: (✓) d) Adequacy of connection at point of entry to enclosure: (✓)		
6.23 Temperature rating of cable insulation adequate: (✓)		
6.24 Condition of accessories including socket-outlets, switches and joint boxes satisfactory: (✓)		
6.25 Suitability of accessories for external influences: (✓)		

PART 11 : SCHEDULES AND ADDITIONAL PAGES

Schedule of Inspections	Schedule of Circuit Details and Test Results for the installation	Additional pages, including data sheets for additional sources	Special installations or locations (indicated in item 9. above)	Continuation sheets
Page No(s): (4 & 5)	Page No(s): (6)	Page No(s): (.....)	Page No(s): (.....)	Page No(s): (N/A)

The pages identified are an essential part of this report (see Regulation 653.2).

All fields must be completed. Enter either, as appropriate: ' ✓ ' if Acceptable condition; ' N/A ' if Not applicable; ' LIM ' if a Limitation exists; or Code appropriately - CODE 'C1', 'C2', 'C3' or 'FI' (codes to be recorded in PART 6, with additional comments (where appropriate) on attached numbered sheets)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 12 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing:

CODES For Type of wiring		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state AWA																		
Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, I _{Δn} Maximum permitted Z _s for installed protective device*	Circuit impedances (Ω)					Insulation resistance			Polarity Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons					
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)		Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)			RCD	AFDD				
													(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ +R ₂)	R ₂											
TP&N	MCCB 1	0	F	1	300	300	5	LIM	LIM	LIM	LIM	LIM					LIM	LIM	LIM	LIM	LIM	LIM	LIM	✓	0.07			

DISTRIBUTION BOARD (DB) DETAILS (to be completed in every case)

DB designation: MCCB 1 SUPPLY
Location of DB: SWITCH ROOM EAST
TESTED BY Name (capitals): GARY BARDRICK
Signature: 
Position: APPROVED ELECTRICIAN
Date: 12/01/2019

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (.....) Nominal voltage: (.....)V No. of phases: (.....)
Overcurrent protection device for the distribution circuit Type: (BS EN) Rating: (.....)A
Associated RCD (if any) Type: (BS EN) No. of poles: (.....) I_{Δn} (.....)mA Operating time: (.....)ms
Characteristics at this DB Confirmation of supply polarity: (.....) Phase sequence confirmed (where appropriate): Z_s (.....)Ω Z_f (.....)kA

TEST INSTRUMENTS

(enter serial number against each instrument used)

Multi-function: (101217148) Continuity: (.....)
Insulation resistance: (.....) Earth fault loop impedance: (.....)
Earth electrode resistance: (.....) RCD: (.....)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 12 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS Circuits/equipment vulnerable to damage when testing:

CODES For Type of wiring		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state AWA																	
Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, I _{Δn} Maximum permitted Z _s for installed protective device*	Circuit impedances (Ω)					Insulation resistance			RCD operating time (ms)	Test buttons					
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)		Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)		Polarity	Max. measured earth fault loop impedance, Z _s (Ω)	RCD	AFDD		
													(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ +R ₂)	R ₂										
TP&N	MCCB 2	0	F	1	300	300	5	LIM	LIM	LIM	LIM	LIM					LIM	LIM	LIM	LIM	LIM	LIM	✓	0.09			

DISTRIBUTION BOARD (DB) DETAILS DB designation: MCCB 2 SUPPLY **TESTED BY** Name (capitals): GARY BARDRICK Position: APPROVED ELECTRICIAN
 (to be completed in every case) Location of DB: Signature:  Date: 12/01/2019

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION
 Supply to DB is from: (.....) Nominal voltage: (.....)V No. of phases: (.....)
Overcurrent protection device for the distribution circuit Type: (BS EN) Rating: (.....)A
Associated RCD (if any) Type: (BS EN) No. of poles: (.....) I_{Δn} (.....)mA Operating time: (.....)ms
Characteristics at this DB Confirmation of supply polarity: (.....) Phase sequence confirmed (where appropriate): Z_s (.....)Ω I_{Δf} (.....)kA

TEST INSTRUMENTS
 (enter serial number against each instrument used)
 Multi-function: (101217148) Continuity: (.....)
 Insulation resistance: (.....) Earth fault loop impedance: (.....)
 Earth electrode resistance: (.....) RCD: (.....)

Original to the person ordering the work

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 12 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing:

CODES For Type of wiring		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state AWA																		
Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, I _{Δn} Maximum permitted Z _s for installed protective device*	Circuit impedances (Ω)					Insulation resistance			Polarity	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons				
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)		Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)				RCD	AFDD			
					(r ₁)	(r _n)	(r ₂)	(R ₁ +R ₂)	R ₂	(MΩ)	(MΩ)		(V)	(ms)														
TP&N	MCCB 3	0	F	1	300	300	5	LIM	LIM	LIM	LIM	LIM					LIM	LIM	LIM	LIM	LIM	LIM	LIM	✓	0.07			

DISTRIBUTION BOARD (DB) DETAILS (to be completed in every case)

DB designation: MCCB 3 SUPPLY **TESTED BY** Name (capitals): GARY BARDRICK Position: APPROVED ELECTRICIAN
 Location of DB: UKPN SUB-STATION Signature:  Date: 12/01/2019

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (.....) Nominal voltage: (.....)V No. of phases: (.....)
Overcurrent protection device for the distribution circuit Type: (BS EN) Rating: (.....)A
Associated RCD (if any) Type: (BS EN) No. of poles: (.....) I_{Δn} (.....)mA Operating time: (.....)ms
Characteristics at this DB Confirmation of supply polarity: (Yes.....) Phase sequence confirmed (where appropriate): Z_s (.....)Ω I_{Δf} (.....)kA

TEST INSTRUMENTS

(enter serial number against each instrument used)

Multi-function: (101217148.....) Continuity: (.....)
 Insulation resistance: (.....) Earth fault loop impedance: (.....)
 Earth electrode resistance: (.....) RCD: (.....)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 12 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS Circuits/equipment vulnerable to damage when testing:

Circuit number	Circuit description	CODES For Type of wiring		Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD		Circuit impedances (Ω)					Insulation resistance			RCD operating time (ms)	Test buttons							
		(A)	(B)				(C)	(D)	(E)	(F)	(G)	(H)	(O)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)	Polarity	Max. measured earth fault loop impedance, Z _s (Ω)	RCD	AFDD	
		Live (mm ²)	cpc (mm ²)				Max. disconnection time (BS 7671) (s)	(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ +R ₂)	R ₂																				
1TP	HEATER 1 - RECEPTION	G	B	1	25	SWA	5	60947-2	MCCB	63	50	N/A	0.36			0.09	>200	>200	500	✓	0.18											
2TP	DB/MECH/1 - LOWER GROUND FLOOR	G	B	1	120	35	5	60947-2	MCCB	250	50	N/A	0.146			0.01	>200	>200	500	✓	0.10											
3TP	DBMECH/2 - ROOF	G	B	1	120	35	5	60947-2	MCCB	250	50	N/A	0.53			0.02	>200	>200	500	✓	0.11											
4TP	DB/MECH/3 - ROOF	G	B	1	120	35	5	60947-2	MCCB	250	50	N/A	0.53			0.02	>200	>200	500	✓	0.11											
5TP	SURGE PROTECTION	D	B	1	16		5	60947-2	MCCB	80	50	N/A	0.28																			
6TP	SPARE																															
7TP	SPARE																															
8TP	SPARE																															
9TP	LIFT 1 SECONDARY	O	B	1	10	SWA	5	60947-2	MCCB	32	50		0.42			0.20	>200	>200	500	✓	0.28											
10TP	RECEPTION HEATER 2	G	B	1	25	SWA	5	60947-2	MCCB	63	50		0.36			0.08	>200	>200	500	✓	0.19											
11TP	SPARE																															
12TP	SPARE																															

DISTRIBUTION BOARD (DB) DETAILS DB designation: MCCB 1 **TESTED BY** Name (capitals): GARY BARDRICK Position: APPROVED ELECTRICIAN
 (to be completed in every case) Location of DB: SWITCH ROOM -EAST Signature: Date: 12/01/2019

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION
 Supply to DB is from: (UKPN SUB-STATION) Nominal voltage: (3 _____) V No. of phases: (400)
Overcurrent protection device for the distribution circuit Type: (BS EN _____) Rating: (600) A
Associated RCD (if any) Type: (BS EN _____) No. of poles: (_____) I_{Δn} (_____) mA Operating time: (_____) ms
Characteristics at this DB Confirmation of supply polarity: (Yes _____) Phase sequence confirmed (where appropriate): Z_s (0.07) Ω I_{Δf} (5.22) kA

TEST INSTRUMENTS
 (enter serial number against each instrument used)
 Multi-function: _____ Continuity: _____
(101217148) _____
 Insulation resistance: _____ Earth fault loop impedance: _____

 Earth electrode resistance: _____ RCD: _____

Original to the person ordering the work

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 12 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing:

Circuit number	Circuit description	CODES For Type of wiring		Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD		Circuit impedances (Ω)					Insulation resistance			RCD operating time (ms)	Test buttons								
		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit				(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state	FP600 SWA	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Ring final circuits only (measured end to end)				All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)	Polarity	Max. measured earth fault loop impedance, Z _s (Ω)	RCD	AFDD
		Live (mm ²)	cpc (mm ²)				Max. disconnection time (BS 7671) (s)	(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ +R ₂)	R ₂																					
1TP	LIFT NO 1 PRIMARY SUPPLY	O	B			1	10	SWA	5	60947-2 MCCB		32	50	N/A	0.46				0.19		>200	>200	500	✓	0.28								
2TP	LIFT NO 2 (UNTRACABLE)	G	B			1	10	SWA	5	60947-2 MCCB		32	50	N/A	0.46				LIM		LIM	LIM	LIM	LIM									
3TP	LIFT NO 3 (UNTRACABLE)	G	B			1	10	SWA	5	60947-2 MCCB		32	50	N/A	0.46				LIM		LIM	LIM	LIM	LIM									
4TP	DB/W/LT/B, DB/W/SP/B	G	B			1	25	16	5	60947-2 MCCB		100	50	N/A	0.23				0.01		>200	>200	500	✓	0.09								
5TP	DB ANNEX 1	G	B			1	25	16	5	60947-2 MCCB		100	50	N/A	0.23				0.01		>200	>200	500	✓	0.09								
6TP	SPARE																																
7TP	DB/LT/ROOF, DB/SP/ROOF	G	B			1	35	SWA	5	60947-2 MCCB		100	50	N/A	0.23				0.02		>200	>200	500	✓	0.11								
8TP	DB/LT/LG, DB/SP/LG	G	B			1	35	SWA	5	60947-2 MCCB		100	50	N/A	0.23				0.01		>200	>200	500	✓	0.11								
9TP	SURGE PROTECTION	D	B			1	16	SWA	5	60947-2 MCCB		80	50	N/A	0.28																		
10TP	SPARE																																
11TP	SPARE																																
12TP	SPARE																																
13TP	SPARE																																
14TP	SPARE																																
15TP	SPARE																																
16TP	SPARE																																
17TP	RISING BUSBAR WEST RISER	G	B			1	240	50	5	60947-2 MCCB		570	50		0.12				0.01		>200	>200	>200	✓	0.09								
18TP	SPARE																																

DISTRIBUTION BOARD (DB) DETAILS (to be completed in every case)

DB designation: MCCB 2 **TESTED BY** Name (capitals): GARY BARDRICK Position: APPROVED ELECTRICIAN
 Location of DB: SWITCH ROOM - WEST Signature: Date: 12/01/2019

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (UKPN SUB-STATION) Nominal voltage: (400) V No. of phases: (3)
Overcurrent protection device for the distribution circuit Type: (BS EN JS TYPE) Rating: (600) A
Associated RCD (if any) Type: (BS EN) No. of poles: (.....) I_{Δn} (.....) mA Operating time: (.....) ms
Characteristics at this DB Confirmation of supply polarity: (Yes.....) Phase sequence confirmed (where appropriate): Z_s (0.09) Ω I_{Δf} (4.44) kA

TEST INSTRUMENTS

(enter serial number against each instrument used)

Multi-function: (101217148) Continuity: (.....)
 Insulation resistance: (.....) Earth fault loop impedance: (.....)
 Earth electrode resistance: (.....) RCD: (.....)



CONTINUATION SHEET:
ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS												Circuits/equipment vulnerable to damage when testing:																						
CODES For Type of wiring		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state	FP600 SWA																							
Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD		Circuit impedances (Ω)					Insulation resistance			Polarity	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons									
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live	Live / Earth	Test voltage DC (V)				RCD	AFDD								
					(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ +R ₂)	R ₂	(MΩ)	(MΩ)	(V)																						
16TP	SPARE																																	
17TP	RISING BUSBAR WEST RISER	G	B	1	240	50	5	60947-2 MCCB		570	50		0.12				0.01		>200	>200	>200	✓	0.09											
18TP	SPARE																																	

DISTRIBUTION BOARD (DB) DETAILS DB designation: MCCB 2 **TESTED BY** Name (capitals): GARY BARDRICK Position: APPROVED ELECTRICIAN
 (to be completed in every case) Location of DB: SWITCH ROOM - WEST Signature: Date: 12/01/2019

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION
 Supply to DB is from: (UKPN SUB-STATION) Nominal voltage: (400) V No. of phases: (3)
Overcurrent protection device for the distribution circuit Type: (BS EN JS TYPE) (JS TYPE) Rating: (600) A
Associated RCD (if any) Type: (BS EN) () No. of poles: () I_{Δn} () mA Operating time: () ms
Characteristics at this DB Confirmation of supply polarity: (Yes) () Phase sequence confirmed (where appropriate): True Z_s (0.09) Ω I_{Δf} (4.44) kA

TEST INSTRUMENTS
 (enter serial number against each instrument used)
 Multi-function: (101217148) Continuity: ()
 Insulation resistance: () Earth fault loop impedance: ()
 Earth electrode resistance: () RCD: ()

Original to the person ordering the work



WEBSTER THOMAS ELECTRICAL LTD

Electrical Contracting Engineers

UNIT 7, CASTLE VIEW BUSINESS ESTATE, GAS HOUSE ROAD, ROCHESTER, KENT. ME11PB

Tel: 01634 818074

This report is not valid if the serial number has been defaced or altered

106181

IPR18

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 12 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing:

Circuit number	Circuit description	CODES For Type of wiring		Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD		Circuit impedances (Ω)			Insulation resistance			Polarity	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons											
		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit				(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state	Live / Live	Live / Earth	Test voltage DC (V)	RCD	AFDD																		
		Live (mm ²)	cpc (mm ²)				Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)						Ring final circuits only (measured end to end)		All circuits (complete at least one column)															
		(Line) r ₁	(Neutral) r _n				(cpc) r ₂	(R ₁ +R ₂)	R ₂	(MΩ)	(MΩ)																									
1TP	SPARE																																			
2L1	SPARE																																			
2L2	SPARE																																			
2L3	FIRE ALARM PANELS	O	B	2	4	4	0.4	60947-2	MCCB	32	50	0.46			0.22	>200	>200	500	✓	0.31																
3TP	DW/W/COMMS/LG	G	B	1	25	16	5	60947-2	MCCB	100	50	0.23			0.06	>200	>200	500	✓	0.11																
4TP	DB/E/LT/B, DB/E/SP/B	G	F	1	25	SWA	5	60947-2	MCCB	100	50	0.23			0.01	>200	>200	500	✓	0.13																
5TP	AHU-BASEMENT	G	F	1	35	16	5	60947-2	MCCB	100	50	0.23			0.01	>200	>200	500	✓	0.09																
6TP	SURGE PROTECTION	D	B	1	16	-	5	60947-2	MCCB	80	80	0.28																								
7TP	SPARE																																			
8TP	SPARE																																			
9TP	SPARE																																			
10TP	SPARE																																			
11TP	RISING BUSBAR EAST RISER	G	F	1	240	50	5	60947-2	MCCB	570	50	N/A	0.12			0.01	>200	>200	500	✓	0.07															
12TP	SPARE																																			

DISTRIBUTION BOARD (DB) DETAILS DB designation: MCCB 3 **TESTED BY** Name (capitals): GARY BARDRICK Position: APPROVED ELECTRICIAN
 (to be completed in every case) Location of DB: SWITCH ROOM EAST Signature: Date: 12/01/2019

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION
 Supply to DB is from: (UKPN SUB-STATION) Nominal voltage: (3) V No. of phases: (400)
 Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (100) A
 Associated RCD (if any) Type: (BS EN JS TYPE) No. of poles: () I_{Δn} () mA Operating time: () ms
 Characteristics at this DB Confirmation of supply polarity: (Yes) Phase sequence confirmed (where appropriate): Z_s (0.07) Ω I_{Δf} (5.49) kA

TEST INSTRUMENTS
 (enter serial number against each instrument used)
 Multi-function: Continuity:
 (101217148)
 Insulation resistance: Earth fault loop impedance:
 Earth electrode resistance: RCD:

Original to the person ordering the work

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 12 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS Circuits/equipment vulnerable to damage when testing:

Circuit number	Circuit description	CODES For Type of wiring		Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Circuit impedances (Ω)					Insulation resistance			RCD operating time (ms)	Test buttons			
		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit				(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state			Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)		Polarity	Max. measured earth fault loop impedance, Z _s (Ω)	RCD	AFDD
		Live (mm ²)	cpc (mm ²)				Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	(Line) r ₁	(Neutral) r _n			(cpc) r ₂	(R ₁ +R ₂)	R ₂										
1TP	A/C UNIT 1	G	B	1	10	10	0.4	60898	MCB	C	32	10	0.68			0.05	>200	>200	500	✓	0.11							
2TP	A/C UNIT 2	G	B	1	10	10	0.4	60898	MCB	C	32	10	0.68			0.05	>200	>200	500	✓	0.11							
3TP	A/C UNIT 3	G	B	1	10	10	0.4	60898	MCB	C	32	10	0.68			0.06	>200	>200	500	✓	0.12							
4TP	SPARE																											
5TP	SPARE																											
6TP	SPARE																											
7TP	SPARE																											
8TP	SPARE																											
9TP	A/C UNIT 4	G	B	1	10	10	0.4	60898	MCB	C	32	10	0.68			0.05	>200	>200	500	✓	0.11							
10TP	A/C UNIT 5	G	B	1	10	10	0.4	60898	MCB	C	32	10	0.68			0.06	>200	>200	500	✓	0.11							
11TP	A/C UNIT 6	G	B	1	10	10	0.4	60898	MCB	C	32	10	0.68			0.05	>200	>200	500		0.11							
12TP	A/C UNIT 7	G	B	1	10	10	0.4	60898	MCB	C	32	10	0.68			0.10	>200	>200	500		0.14							
13TP	SPARE																											
14TP	SPARE																											
15TP	SPARE																											
16TP	KWH METER	G	B	1	1	10	0.4	60898	MCB	B	2	10	21.85															

DISTRIBUTION BOARD (DB) DETAILS (to be completed in every case) DB designation: DB/MECH/1 **TESTED BY** Name (capitals): GARY BARDRICK Position: APPROVED ELECTRICIAN
 Location of DB: LOWER GROUND FLOOR STORE Signature: Date: 12/01/2019

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION
 Supply to DB is from: (MCCB 1) Nominal voltage: (400) V No. of phases: (3)
 Overcurrent protection device for the distribution circuit Type: (BS EN BS EN 60947-2) Rating: (250) A
 Associated RCD (if any) Type: (BS EN) No. of poles: () I_{Δn} () mA Operating time: () ms
 Characteristics at this DB Confirmation of supply polarity: (Yes) Phase sequence confirmed (where appropriate): Z_s (0.10) Ω I_{Δf} (5.51) kA

TEST INSTRUMENTS (enter serial number against each instrument used)
 Multi-function: (101217148) Continuity: ()
 Insulation resistance: () Earth fault loop impedance: ()
 Earth electrode resistance: () RCD: ()

Original to the person ordering the work

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

Original to the person ordering the work

PART 12 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing:

Circuit number	Circuit description	CODES For Type of wiring		Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD		Circuit impedances (Ω)					Insulation resistance			Polarity	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons					
		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit				(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Ring final circuits only (measured end to end)			All circuits (complete at least one column)				Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)	RCD	AFDD	
		Live (mm ²)	cpc (mm ²)				Max. disconnection time (BS 7671) (s)	(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ +R ₂)	R ₂																				
1TP	CONDENSER UNIT CU/01	G	E	G	E	1	6.0	4.0	5	60898	MCCB	C	40	10	0.55				0.06		>200	>200	500	✓	0.13							
2TP	CONDENSER UNIT CU/01	G	E	G	E	1	6.0	4.0	5	60898	MCCB	C	40	10	0.55				0.06		>200	>200	500	✓	0.13							
3TP	CONDENSER UNIT CU/02	G	E	G	E	1	6.0	4.0	5	60898	MCCB	C	40	10	0.55				0.05		>200	>200	500	✓	0.14							
4TP	CONDENSER UNIT CU/02	G	E	G	E	1	6.0	4.0	5	60898	MCCB	C	40	10	0.55				0.06		>200	>200	500	✓	0.14							
5TP	CONDENSER UNIT CU/03	G	E	G	E	1	6.0	4.0	5	60898	MCCB	C	40	10	0.55				0.08		>200	>200	500	✓	0.14							
6TP	CONDENSER UNIT CU/03	G	E	G	E	1	6.0	4.0	5	60898	MCCB	C	40	10	0.55				0.07		>200	>200	500	✓	0.13							
7TP	CONDENSER UNIT CU/04	G	E	G	E	1	6.0	4.0	5	60898	MCCB	C	40	10	0.55				0.07		>200	>200	500	✓	0.13							
8TP	CONDENSER UNIT CU/04	G	E	G	E	1	6.0	4.0	5	60898	MCCB	C	40	10	0.55				0.06		>200	>200	500	✓	0.12							
9L1	HEATER DIS WC	D	B	D	B	1	4	4	0.4	60898	MCCB	C	20	10	1.09				0.07		>200	>200	500	✓	0.20							
9L2	HEATER WC	D	B	D	B	1	4	4	0.4	60898	MCCB	C	20	10	1.09				0.07		>200	>200	500	✓	0.20							
9L3	WH FOOD PREP AREA	D	B	D	B	1	4	4	0.4	60898	MCCB	C	20	10	1.09				0.16		>200	>200	500	✓	0.20							
10L1	W/HEATER WC	D	B	D	B	1	4	4	0.4	60898	MCCB	C	20	10	1.09				0.06		>200	>200	500	✓	0.18							
10L2	AERIAL BOOSTER	G	B	G	B	1	4	4	0.4	60898	MCCB	C	20	10	1.09				0.12		>200	>200	500	✓	0.24							
10L3	AC UNIT CAFE (SPARE)	D	B	D	B	2	4	4	0.4	60898	MCCB	C	20	10	1.09				0.08		>200	>200	500	✓	0.20							
11L1	SERVERY EXTRACT FAN (UNTRACEBLE)	D	B	D	B	1	2.5	2.5	0.4	60898	MCCB	C	20	10	1.09				LIM		LIM	LIM	LIM	✓	LIM							
11L2	WC EXTRACT FAN (UNTRACEBLE)	D	B	D	B	1	2.5	2.5	0.4	60898	MCCB	C	20	10	1.09				LIM		LIM	LIM	LIM	✓	LIM							
11L3	WH + INSECT KILLER	D	B	D	B	2	2.5	2.5	0.4	60898	MCCB	C	20	10	1.09				0.06		>200	>200	500	✓	0.17							
12TP	PREP ROOM OVEN	G	E	G	E	1	4	4	0.4	60898	MCCB	C	20	10	1.09																	
13L1	PREP ROOM AC	G	E	G	E	1	4	4	0.4	60898	MCCB	C	20	10	1.09				0.03		>200	>200	500	✓	0.16							
13L2	SPARE																															

DISTRIBUTION BOARD (DB) DETAILS (to be completed in every case)

DB designation: DB/MECH/2 **TESTED BY** Name (capitals): GARY BARDRICK Position: APPROVED ELECTRICIAN

Location of DB: ROOF Signature: Date: 12/01/2019

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (MCCB 1) Nominal voltage: (400) V No. of phases: (3)

Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (250) A

Associated RCD (if any) Type: (BS EN) No. of poles: (.....) I_{Δn} (.....) mA Operating time: (.....) ms

Characteristics at this DB Confirmation of supply polarity: (Yes.....) Phase sequence confirmed (where appropriate): Z_s (0.11.....) Ω I_{Δf} (2.77.....) kA

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: (101217148) Continuity: (.....)

Insulation resistance: (.....) Earth fault loop impedance: (.....)

Earth electrode resistance: (.....) RCD: (.....)



CONTINUATION SHEET:
ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS													Circuits/equipment vulnerable to damage when testing:														
CODES For Type of wiring		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state			RCD		Circuit impedances (Ω)			Insulation resistance			Polarity	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons			
Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)				Test voltage DC (V)	RCD	AFDD	
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ +R ₂)	R ₂									
																					(ms)	(ms)					
13L3	SPARE																										
14L3	HEATED GANTRY	G	B	1	4	4	0.4	61009 RCD/RCBO	C	20	10	30	1.09														
15TP	COMBI OVEN	G	B	1	4	4	0.4	60898 MCCB	C	20	10		1.09			0.01		>200	>200	500	✓	0.15					
16TP	KWH METER	D	B	1	1.5		0.4	60898 MCCB	C	2	10		10.93								✓						

DISTRIBUTION BOARD (DB) DETAILS
 (to be completed in every case)

DB designation: DB/MECH/2 **TESTED BY** Name (capitals): GARY BARDRICK Position: APPROVED ELECTRICIAN
 Location of DB: ROOF Signature: Date: 12/01/2019

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (MCCB 1) Nominal voltage: (400) V No. of phases: (3)
 Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (250) A
 Associated RCD (if any) Type: (BS EN) No. of poles: (.....) I_{Δn} (.....) mA Operating time: (.....) ms
 Characteristics at this DB Confirmation of supply polarity: (Yes.....) Phase sequence confirmed (where appropriate): True Z_s (0.11.....) Ω I_{Δf} (2.77.....) kA

TEST INSTRUMENTS

(enter serial number against each instrument used)
 Multi-function: (.....) Continuity: (.....)
 (101217148.....) (.....)
 Insulation resistance: (.....) Earth fault loop impedance: (.....)
 Earth electrode resistance: (.....) RCD: (.....)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 12 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing:

Circuit number	Circuit description	CODES For Type of wiring		Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD		Circuit impedances (Ω)			Insulation resistance			Polarity	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons					
		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit				(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Ring final circuits only (measured end to end)					All circuits (complete at least one column)			RCD	AFDD	
		Live (mm ²)	cpc (mm ²)				Max. disconnection time (BS 7671) (s)	(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ +R ₂)	R ₂	Live / Live (MΩ)							Live / Earth (MΩ)	Test voltage DC (V)									
1TP	CONDENSER UNIT CU/00	G	F	1	6	4	5	60898	MCCB	C	40	10	N/A	0.55	0.06				>200	>200	500	✓	0.12							
2TP	CONDENSER UNIT CU/00	G	F	1	6	4	5	60898	MCCB	C	40	10	N/A	0.55	0.06				>200	>200	500	✓	0.13							
3TP	CONDENSER UNIT CU/05-01	G	F	1	6	4	5	60898	MCCB	C	40	10	N/A	0.55	0.07				>200	>200	500	✓	0.13							
4TP	CONDENSER UNIT CU/05-01	G	F	1	6	4	5	60898	MCCB	C	40	10	N/A	0.55	0.06				>200	>200	500	✓	0.13							
5TP	CONDENSER UNIT CU/06	G	F	1	6	4	5	60898	MCCB	C	40	10	N/A	0.55	0.07				>200	>200	500	✓	0.14							
6TP	CONDENSER UNIT CU/06	G	F	1	6	4	5	60898	MCCB	C	40	10	N/A	0.55	0.07				>200	>200	500	✓	0.14							
7TP	CONDENSER UNIT CU/LG	G	F	1	6	4	5	60898	MCCB	C	40	10	N/A	0.55	0.07				>200	>200	500	✓	0.15							
8TP	CONDENSER UNIT CU/LG	G	F	1	6	4	5	60898	MCCB	C	40	10	N/A	0.55	0.06				>200	>200	500	✓	0.15							
9L1	CONDENSER UNIT CU/LG	G	F	1	6	4	5	60898	MCCB	C	40	10	N/A	0.55	0.04				>200	>200	500	✓	0.11							
9L2	SPARE																													
9L3	SPARE																													
10TP	SPARE																													
11TP	SPARE																													
12TP	SPARE																													
13TP	SPARE																													
14TP	SPARE																													
15TP	SPARE																													
16TP	KWA METER	D	B	1	1.5		0.4	60898	MCCB	C	2	10	N/A	10.93																

DISTRIBUTION BOARD (DB) DETAILS (to be completed in every case)

DB designation: DB/MECH/3 **TESTED BY** Name (capitals): GARY BARDRICK Position: APPROVED ELECTRICIAN
 Location of DB: ROOF Signature: Date: 12/01/2019

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (MCCB 1) Nominal voltage: (400) V No. of phases: (3)
 Overcurrent protection device for the distribution circuit Type: (BS EN) Rating: (250) A
 Associated RCD (if any) Type: (BS EN 608947-2) No. of poles: (.....) I_{Δn} (.....) mA Operating time: (.....) ms
 Characteristics at this DB Confirmation of supply polarity: (Yes.....) Phase sequence confirmed (where appropriate): Z_s (0.11) Ω I_{Δf} (2.77) kA

TEST INSTRUMENTS

(enter serial number against each instrument used)

Multi-function: (.....) Continuity: (.....)
 (101217148) Insulation resistance: (.....) Earth fault loop impedance: (.....)
 Earth electrode resistance: (.....) RCD: (.....)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

Original to the person ordering the work

PART 12 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing:

CODES For Type of wiring		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state	FP200															
Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD		Circuit impedances (Ω)			Insulation resistance			RCD operating time (ms)	Test buttons					
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Ring final circuits only (measured end to end)			All circuits (complete at least one column)				Polarity	Max. measured earth fault loop impedance, Z _s (Ω)	RCD	AFDD		
														(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ +R ₂)	R ₂	Live / Live (MΩ)						Live / Earth (MΩ)	Test voltage DC (V)
1L1	LIGHTING - RECEPTION DOWNLIGHTS	0	B	12	2.5	2.5	0.4	60898 MCB	C	6	10	N/A	3.64			1.36		LIM	>200	500	✓	0.91				
1L2	LIGHTING - RECEPTION OFFICE LCM	0	B	1	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	2.18			0.25		>200	>200	500	✓	0.39				
1L3	LIGHTING - MEZZANINE WC LCM	0	B	1	2.5	2.5	0.4	61009 RCD/RCBO	C	10	10	30	2.18			0.09		>200	>200	500	✓	0.27	28.7	✓		
2L1	LIGHTING - LIFT LOBBY	0	B	9	2.5	2.5	0.4	60898 MCB	D	10	10	N/A	1.09			0.46		LIM	>200	500	✓	0.62				
2L2	LIGHTING - BIKE STORE SHOWERS LCM	0	B	12	2.5	2.5	0.4	61009 RCD/RCBO	C	10	10	30	2.18			0.22		LIM	>200	500	✓	0.35	28.6	✓		
2L3	LIGHTING - BARRASOL	0	B	2	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	2.18			0.64		>200	>200	500	✓	0.78				
3L1	LIGHTING - RECEPTION DOWNLIGHTS	0	B	11	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	2.18			1.15		>200	>200	500	✓	1.28				
3L2	LIGHTING - BARRASOL	0	B	2	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	2.18			0.40		>200	>200	500	✓	0.54				
3L3	LIGHTING - LED FLOOR LIGHTS	0	B	4	2.5	2.5	0.4	60898 MCB	D	10	10	N/A	1.09			0.47		>200	>200	500	✓	0.65				
4L1	LIGHTING - RECEPTION WALL (UNTRACABLE)	0	B	2	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	2.18			LIM		LIM	LIM	LIM		LIM				
4L2	LIGHTING - BIKE STORE & BIN AREA	0	B	5	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	2.18			0.16		LIM	>200	500	✓	0.32				
4L3	SPARE																									
5L1	SPARE																									
5L2	SPARE																									
5L3	SPARE																									
6TP	KWH METER	D	B	1	1.5		0.4	60898 MCB	C	2	10	N/A	10.93													

DISTRIBUTION BOARD (DB) DETAILS DB designation: DB/LT/REC **TESTED BY** Name (capitals): GARY BARDRICK Position: APPROVED ELECTRICIAN
 (to be completed in every case) Location of DB: RECEPTION OFFICE Signature: [Signature] Date: 12/01/2019

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION
 Supply to DB is from: (RISING BUSBAR TAP OFF) Nominal voltage: (3 _____) V No. of phases: (400 _____)
Overcurrent protection device for the distribution circuit Type: (BS EN 88) Rating: (100 _____) A
Associated RCD (if any) Type: (BS EN N/A) No. of poles: (3 _____) I_{Δn} (N/A _____) mA Operating time: (N/A _____) ms
Characteristics at this DB Confirmation of supply polarity: (Yes _____) Phase sequence confirmed (where appropriate): Z_s (0.13 _____) Ω Z_f (2.94 _____) kA

TEST INSTRUMENTS
 (enter serial number against each instrument used)
 Multi-function: _____ Continuity: _____
 (101217148) _____
 Insulation resistance: _____ Earth fault loop impedance: _____

 Earth electrode resistance: _____ RCD: _____

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 12 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing:

Circuit number	Circuit description	CODES For Type of wiring		Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD		Circuit impedances (Ω)					Insulation resistance			RCD operating time (ms)	Test buttons							
		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit				(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)	Polarity	Max. measured earth fault loop impedance, Z _s (Ω)	RCD	AFDD	
		Live (mm ²)	cpc (mm ²)				Max. disconnection time (BS 7671) (s)	(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ +R ₂)	R ₂																				
1L1	DECK PERIMETER LIGHTING SOUTH	G	B	G	B	3	2.5	2.5	0.4	60898	C	10	10	2.18				0.65		LIM	>200	500	✓	0.75								
1L2	DECK PERIMETER LIGHTING NORTH	G	B	G	B	4	2.5	2.5	0.4	60898	C	10	10	2.18				0.61		LIM	>200	500	✓	0.62								
1L3	DECK UPLIGHTERS + GLASS BOX	G	B	G	B	2	2.5	2.5	0.4	60898	C	10	10	2.18				0.62		LIM	>200	500	✓	0.73								
2L1	PERIMETER BULKHEADS NORTH	D	B	D	B	9	2.5	2.5	0.4	60898	C	10	10	2.18				0.74		LIM	>200	500	✓	0.84								
2L2	PERIMETER BULKHEADS SOUTH	D	B	D	B	7	2.5	2.5	0.4	60898	C	10	10	2.18				0.89		LIM	>200	500	✓	0.99								
2L3	CONDENSER FARM LIGHTING	G	B	G	B	6	2.5	2.5	0.4	60898	C	10	10	2.18				0.47		LIM	>200	500	✓	0.57								
3L1	FOOD PREP & LIFT LOBBY LIGHTING	D	B	D	B	12	2.5	2.5	0.4	60898	C	10	10	2.18				0.41		LIM	>200	500	✓	0.51								
3L2	WC LIGHTING	D	B	D	B	10	2.5	2.5	0.4	60898	C	10	10	2.18				0.56		LIM	>200	500	✓	0.66								
3L3	BOUYS PENDANTS	D	B	D	B	22	2.5	2.5	0.4	60898	C	10	10	2.18				0.73		LIM	>200	500	✓	0.83								
4L1	CAFE H/L BULKHEADS	D	B	D	B	15	2.5	2.5	0.4	60898	C	10	10	2.18				0.67		LIM	>200	500	✓	0.78								
4L2	KITCHEN DOWNLIGHTER	D	B	D	B	10	2.5	2.5	0.4	60898	C	10	10	2.18				0.48		LIM	>200	500	✓	0.59								
4L3	5X TWIN WALL LIGHTS	D	B	D	B	5	2.5	2.5	0.4	60898	C	10	10	2.18				0.61		LIM	>200	500	✓	0.72								
5L1	EXIT LIGHTS, CONTACTOR PHOTO CELL	D	B	D	B	1	2.5	2.5	0.4	60898	C	10	10	2.18				0.02		LIM	>200	500	✓	0.12								
5L2	SPARE																															
5L3	DISABLED ALARM	D	B	D	B	1	2.5	2.5	0.4	60898	C	10	10	2.18				0.24		LIM	>200	500	✓	0.35								
6TP	KWH METER	D	B	D	B	1	2.5	2.5	0.4	60898	C	2	10	10.93																		

DISTRIBUTION BOARD (DB) DETAILS DB designation: DB/LT/R **TESTED BY** Name (capitals): GARY BARDRICK Position: APPROVED ELECTRICIAN
 (to be completed in every case) Location of DB: ROOF ELECTRICAL CUPBOARD Signature: Date: 12/01/2019

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION
 Supply to DB is from: (MCCB 2) Nominal voltage: (3) V No. of phases: (400)
 Overcurrent protection device for the distribution circuit Type: (BS EN) Rating: (.....) A
 Associated RCD (if any) Type: (BS EN 60947-2) No. of poles: (100) I_{Δn} (.....) mA Operating time: (.....) ms
 Characteristics at this DB Confirmation of supply polarity: (Yes.....) Phase sequence confirmed (where appropriate): Z_s (0.10.....) Ω I_{Δf} (3.14.....) kA

TEST INSTRUMENTS
 (enter serial number against each instrument used)
 Multi-function: (101217148) Continuity: (.....)
 Insulation resistance: (.....) Earth fault loop impedance: (.....)
 Earth electrode resistance: (.....) RCD: (.....)

Original to the person ordering the work

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 12 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing:

Circuit number	Circuit description	CODES For Type of wiring		Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD		Circuit impedances (Ω)					Insulation resistance			Polarity	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons		
		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit				(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state	FP200	Ring final circuits only (measured end to end)		All circuits (complete at least one column)			Live / Live	Live / Earth	Test voltage DC	RCD				AFDD		
		Live (mm ²)	cpc (mm ²)				Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ +R ₂)	R ₂	(MΩ)	(MΩ)	(V)								
1L1	HAND DRYERS CIRCUIT NO.1	O			B	2	4.0	4.0	0.4	60898 MCB	C	20	10	1.09				0.10		>200	>200	500	✓	0.20					
1L2	HAND DRYERS CIRCUIT NO.2	O			B	2	4.0	4.0	0.4	60898 MCB	C	20	10	1.09				0.10		>200	>200	500	✓	0.20					
1L3	FRIDGE, DIS W/C	O			B	1	4.0	4.0	0.4	60898 MCB	C	20	10	1.09				0.11		>200	>200	500	✓	0.20					
2L1	UPRIGHT FRIDGE NO.1 (UNTRACABLE)	O			B	1	4.0	4.0	0.4	60898 MCB	C	20	10	1.09				LIM		LIM	LIM	LIM		LIM					
2L2	UPRIGHT FRIDGE NO.2	O			B	1	4.0	4.0	0.4	60898 MCB	C	20	10	1.09				0.09		>200	>200	500	✓	0.19					
2L3	UPRIGHT FREEZER NO.1	O			B	1	4.0	4.0	0.4	60898 MCB	C	20	10	1.09															
3L1	GENERAL POWER - FOOD PREP/STORE	O			B	6	4.0	4.0	0.4	61009/RCD/RCBO	C	32	10	30	0.68	0.21	0.21	0.21	0.09		>200	>200	500	✓	0.16	28.8	✓		
3L2	GENERAL POWER - CLEANERS	O			B	3	4.0	4.0	0.4	61009 RCD/RCBO	C	32	10	30	0.68				0.19		>200	>200	500	✓	0.30	28.9	✓		
3L3	GENERAL POWER - CAFE	O			B	7	4.0	4.0	0.4	61009 RCD/RCBO	C	20	10	30	1.09				0.18		>200	>200	500	✓	0.28	28.9	✓		
4L1	GENERAL POWER OUTSIDE BENCH	O			B	8	4.0	4.0	0.4	61009 RCD/RCBO	C	32	10	30	0.68	0.38	0.38	0.38	0.16		>200	>200	500	✓	0.27	29.9	✓		
4L2	VIVREAU AND DOUBLE SOCKET OUTLET	O			B	2	4.0	4.0	0.4	61009 RCD/RCBO	C	32	10	30	0.68	0.21	0.21	0.21	0.09		>200	>200	500	✓	0.19	28.9	✓		
4L3	GENERAL POWER CAFE	F			B	4	4.0	4.0	0.4	61009 RCD/RCBO	C	20	10	30	1.09				0.32		>200	>200	500	✓	0.42	28.9	✓		
5L1	POWER OUTSIDE SOUTH	F			B	1	4.0	4.0	0.4	61009 RCD/RCBO	C	20	10	30	1.09				0.42		>200	>200	500	✓	0.52	28.9	✓		
5L2	POWER SERVRY	O			B	2	4.0	4.0	0.4	61009 RCD/RCBO	C	20	10	30	1.09				0.18		>200	>200	500	✓	0.28	29.0	✓		
5L3	POWER SERVRY	O			B	1	4.0	4.0	0.4	61009 RCD/RCBO	C	20	10	30	1.09				0.14		>200	>200	500	✓	0.24	28.8	✓		
6L1	POWER OUTSIDE WEST	F			B	1	4.0	4.0	0.4	61009 RCD/RCBO	C	20	10	30	1.09				0.12		>200	>200	500	✓	0.22	28.9	✓		
6L2	KITCHEN UNIT DB	F			B	1	10.0	10.0	5	60898 MCB	C	40	10		0.55				0.10		>200	>200	500	✓	0.20				
6L3	W/HEATER SERVRY	O			B	2	4.0	4.0	0.4	60898 MCB	C	32	10		0.68				0.16		>200	>200	500	✓	0.26				
7L1	DISHWASHER BAR	O			B	1	4.0	4.0	0.4	60898 MCB	C	32	10		0.68				0.15		>200	>200	500	✓	0.25				
7L2	TALL FRIDGE	O			B	2	4.0	4.0	0.4	60898 MCB	C	20	10		1.09				0.09		>200	>200	500	✓	0.18				

DISTRIBUTION BOARD (DB) DETAILS (to be completed in every case)
 DB designation: DB/SP/ROOF
 Location of DB: ROOF ELECTRICAL CUPBAORD
TESTED BY Name (capitals): GARY BARDRICK
 Signature:
 Position: APPROVED ELECTRICIAN
 Date: 12/01/2019

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION
 Supply to DB is from: (MCCB2) Nominal voltage: (400) V No. of phases: (3)
 Overcurrent protection device for the distribution circuit Type: (BS EN BS EN 60947-2 MCCB) Rating: (100) A
 Associated RCD (if any) Type: (BS EN) No. of poles: (.....) I_{Δn} (.....) mA Operating time: (.....) ms
 Characteristics at this DB Confirmation of supply polarity: (Yes.....) Phase sequence confirmed (where appropriate): Z_s (0.11.....) Ω I_f (3.21.....) kA

TEST INSTRUMENTS (enter serial number against each instrument used)
 Multi-function: (101217148) Continuity: (.....)
 Insulation resistance: (.....) Earth fault loop impedance: (.....)
 Earth electrode resistance: (.....) RCD: (.....)

Original to the person ordering the work

CONTINUATION SHEET:
ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing:

Circuit number	Circuit description	CODES For Type of wiring		Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD		Circuit impedances (Ω)			Insulation resistance			RCD operating time (ms)	Test buttons								
		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit				(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state	FP200	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Ring final circuits only (measured end to end)			All circuits (complete at least one column)			Polarity	Max. measured earth fault loop impedance, Z _s (Ω)	RCD	AFDD	
		Live (mm ²)	cpc (mm ²)				Max. disconnection time (BS 7671) (s)	(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ +R ₂)	R ₂	Live / Live (MΩ)	Live / Earth (MΩ)							Test voltage DC (V)										
7L1	DISHWASHER BAR	0	B	1	4.0	4.0	0.4	60898	MCB	C	32	10		0.68			0.15		>200	>200	500	✓	0.25								
7L2	TALL FRIDGE	0	B	2	4.0	4.0	0.4	60898	MCB	C	20	10		1.09			0.09		>200	>200	500	✓	0.18								
7L3	COFFEE MACHINE	0	B	1	6.0	6.0	0.4	60898	MCB	C	32	10		0.68			0.14		>200	>200	500	✓	0.24								
8L1	OVEN SUPPLY - (ROBAND)	0	B	1	4.0	4.0	0.4	60898	MCB	C	20	10		1.09			0.15		>200	>200	500	✓	0.25								
8L2	BOOTLE COOLER SUPPLY	0	B	2	4.0	4.0	0.4	60898	MCB	C	20	10		1.09			0.14		>200	>200	500	✓	0.24								
8L3	DISHWASHER	0	B	2	4.0	4.0	0.4	61009	RCD/RCBO	C	20	10	30	1.09			0.18		>200	>200	500	✓	0.29	28.9	✓						
9L1	WATER HEATER - CAFE	0	B	1	4.0	4.0	0.4	60898	MCB	C	20	10		1.09			0.14		>200	>200	500	✓	0.23								
9L2	WATER HEATER - FOOD PREP/STORE	0	B	1	4.0	4.0	0.4	60898	MCB	C	20	10		1.09			0.14		>200	>200	500	✓	0.24								
9L3	DISABLED ALARM	0	B	1	4.0	4.0	0.4	60898	MCB	C	20	10		1.09			0.11		>200	>200	500	✓	0.20								
10TP	SPARE																														
11TP	SPARE																														
12TP	SPARE																														

DISTRIBUTION BOARD (DB) DETAILS
 (to be completed in every case)

DB designation: DB/SP/ROOF **TESTED BY** Name (capitals): GARY BARDRICK Position: APPROVED ELECTRICIAN
 Location of DB: ROOF ELECTRICAL CUPBOARD Signature: Date: 12/01/2019

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (MCCB2) Nominal voltage: (400) V No. of phases: (3)
Overcurrent protection device for the distribution circuit Type: (BS EN BS EN 60947-2 MCCB) Rating: (100) A
Associated RCD (if any) Type: (BS EN) No. of poles: (.....) I_{Δn} (.....) mA Operating time: (.....) ms
Characteristics at this DB Confirmation of supply polarity: (Yes.....) Phase sequence confirmed (where appropriate): True Z_s (0.11) Ω I_{Δf} (3.21) kA

TEST INSTRUMENTS

(enter serial number against each instrument used)
 Multi-function: (.....) Continuity: (.....)
(101217148) (.....)
 Insulation resistance: (.....) Earth fault loop impedance: (.....)
 Earth electrode resistance: (.....) RCD: (.....)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 12 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing:

Circuit number	Circuit description	CODES For Type of wiring		Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD		Circuit impedances (Ω)			Insulation resistance			Polarity	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons					
		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit				(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Ring final circuits only (measured end to end)					All circuits (complete at least one column)			RCD	AFDD	
		Live (mm ²)	cpc (mm ²)				Max. disconnection time (BS 7671) (s)	(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ +R ₂)	R ₂	Live / Live (MΩ)							Live / Earth (MΩ)	Test voltage DC (V)									
1	LIGHTING - CENTRAL STAIRCASE PIR'S	B	B	9	1.5	1.5	0.4	60898 MCCB	C	6	10	N/A	3.64			0.42		LIM	>200	500	✓	0.53								
2	LIGHTING CENTRAL STAIRCASE GND - 2ND	B	B	14	1.5	1.5	0.4	60898 MCCB	C	10	10	N/A	2.18			0.55		LIM	>200	500	✓	0.77								
3	LIGHTING - PIR CENTRAL STAIRCASE - 2ND - ROOF	B	B	20	1.5	1.5	0.4	60898 MCCB	C	10	10	N/A	2.18			0.75		LIM	>200	500	✓	0.97								
4	SPARE																													
5	SPARE																													
6	SPARE																													

DISTRIBUTION BOARD (DB) DETAILS (to be completed in every case)

DB designation: DB/C/LT/2 **TESTED BY** Name (capitals): GARY BARDRICK Position: APPROVED ELECTRICIAN
 Location of DB: WC CLEANERS CUPBOARD 2ND Signature: Date: 12/01/2019

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (DB/W/LT/2) Nominal voltage: (230) V No. of phases: (1)
Overcurrent protection device for the distribution circuit Type: (BS EN 60898) Rating: (32) A
Associated RCD (if any) Type: (BS EN) No. of poles: (.....) I_{Δn} (.....) mA Operating time: (.....) ms
Characteristics at this DB Confirmation of supply polarity: (Yes.....) Phase sequence confirmed (where appropriate): Z_s (0.21) Ω I_{Δf} (1.11) kA

TEST INSTRUMENTS

(enter serial number against each instrument used)
 Multi-function: (101217148) Continuity: (.....)
 Insulation resistance: (.....) Earth fault loop impedance: (.....)
 Earth electrode resistance: (.....) RCD: (.....)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 12 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing:

Circuit number	Circuit description	CODES For Type of wiring		Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD		Circuit impedances (Ω)					Insulation resistance			Polarity	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons									
		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit				(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state	0 = MODULAR WIRING P= FP200	Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)				Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)	RCD	AFDD
															(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ +R ₂)	R ₂																	
1L1	FAN COIL UNITS (UNTRACABLE)	O	B	2	4	4	0.4	60898	MCB	C	20	10	1.09				LIM		LIM	LIM	LIM	LIM														
1L2	BOILER & EXTRACT FAN - BIKE STORE	G	B	2	4	4	0.4	60898	MCB	C	20	10	1.09				0.41		>200	>200	500	✓	0.23													
1L3	HAND DRYER MEZZANINE WC	G	B	1	4	4	0.4	60898	MCB	C	20	10	1.09				0.18		>200	>200	500	✓	0.22													
2L1	FAN COIL UNITS (UNTRACABLE)	O	B	5	4	4	0.4	60898	MCB	C	20	10	1.09				LIM		LIM	LIM	LIM	LIM														
2L2	CLEANERS SOCKETS BIKE STORE	G	B	3	4	4	0.4	61009	RCD/RCBO	C	32	10	30	0.68	0.30	0.30	0.30	0.16		>200	>200	500	✓	0.28	28.9	✓										
2L3	WATER HEATER MEZZANINE FLOOR WC	G	B	1	4	4	0.4	60898	MCB	C	20	10	1.09				0.08		>200	>200	500	✓	0.18													
3L1	COFFEE MACHINE SOCKETS RECEPTION	G	B	4	4	4	0.4	61009	RCD/RCBO	C	32	10	30	0.68	0.43	0.43	0.31	0.08		>200	>200	500	✓	0.39	29.1	✓										
3L2	DOOR MOTOR	G	B	1	4	4	0.4	60898	MCB	C	32	10	1.09				0.22		>200	>200	500	✓	0.32													
3L3	GENERAL POWER RECEPTION DESK	G	B	1	4	4	0.4	61009	RCD/RCBO	C	32	10	30	0.68	0.15	0.15	0.15	0.08		>200	>200	500	✓	0.19	28.8	✓										
4L1	CLEANERS SOCKETS RECEPTION DESK	G	B	4	4	4	0.4	61009	RCD/RCBO	C	32	10	30	0.68	0.58	0.58	0.29	0.22		>200	>200	500	✓	0.43	28.8	✓										
4L2	GENERAL POWER RECEPTION OFFICE	G	B	8	4	4	0.4	61009	RCD/RCBO	C	32	10	30	0.68	0.30	0.30	0.13	0.12		>200	>200	500	✓	0.21	22.7	✓										
4L3	GENERAL POWER RECEPTION DESK	G	B	1	4	4	0.4	61009	RCD/RCBO	C	32	10	30	0.68	0.21	0.21	0.21	0.11		>200	>200	500	✓	0.14	28.9	✓										
5L1	FAN COIL UNITS - BIKE STORE	G	B	1	4	4	0.4	60898	MCB	C	20	10	1.09				0.12		>200	>200	500	✓	0.21													
5L2	TOWEL RAIL BIKE STORE	P	B	5	4	4	0.4	61009	RCD/RCBO	C	32	10	30	0.68	0.16	0.16	0.14	0.09		>200	>200	500	✓	0.24	29.1	✓										
5L3	SPARE																																			
6L1	SPARE																																			
6L2	HAND DRYERS BIKE STORE	P	B	5	4	4	0.4	61009	RCD/RCBO	C	32	10	30	0.68	0.13	0.13	0.13	0.08		>200	>200	500	✓	0.24	29	✓										
6L3	SPARE																																			
7L1	SPARE																																			
7L2	SPARE																																			

DISTRIBUTION BOARD (DB) DETAILS (to be completed in every case)

DB designation: DB/SP/REC **TESTED BY** Name (capitals): GARY BARDRICK Position: APPROVED ELECTRICIAN

Location of DB: RECEPTION Signature:  Date: 12/01/2019

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (RISING BUS BAR TAP OFF) Nominal voltage: (400) V No. of phases: (3)

Overcurrent protection device for the distribution circuit Type: (BS EN 88) Rating: (100) A

Associated RCD (if any) Type: (BS EN) No. of poles: (.....) I_{Δn} (.....) mA Operating time: (.....) ms

Characteristics at this DB Confirmation of supply polarity: (Yes.....) Phase sequence confirmed (where appropriate): Z_s (0.12) Ω I_{Δf} (3.20) kA

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: (101217148) Continuity: (.....)

Insulation resistance: (.....) Earth fault loop impedance: (.....)

Earth electrode resistance: (.....) RCD: (.....)

Original to the person ordering the work

CONTINUATION SHEET:
ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing:

CODES For Type of wiring		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state	O = MODULAR WIRING P= FP200																									
Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Circuit impedances (Ω)					Insulation resistance			Polarity	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons											
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)				RCD	AFDD										
														(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ +R ₂)	R ₂																		
7L1	SPARE																																			
7L2	SPARE																																			
7L3	SPARE																																			
8L1	SPARE																																			
8L2	SPARE																																			
8L3	SPARE																																			

DISTRIBUTION BOARD (DB) DETAILS DB designation: DB/SP/REC **TESTED BY** Name (capitals): GARY BARDRICK Position: APPROVED ELECTRICIAN
 (to be completed in every case) Location of DB: RECEPTION Signature: Date: 12/01/2019

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION
 Supply to DB is from: (RISING BUS BAR TAP OFF) Nominal voltage: (400) V No. of phases: (3)
Overcurrent protection device for the distribution circuit Type: (BS EN 88) Rating: (100) A
Associated RCD (if any) Type: (BS EN) No. of poles: (.....) I_{Δn} (.....) mA Operating time: (.....) ms
Characteristics at this DB Confirmation of supply polarity: (Yes.....) Phase sequence confirmed (where appropriate): True Z_s (0.12.....) Ω I_{Δf} (3.20.....) kA

TEST INSTRUMENTS
 (enter serial number against each instrument used)
 Multi-function: (101217148.....) Continuity: (.....)
 Insulation resistance: (.....) Earth fault loop impedance: (.....)
 Earth electrode resistance: (.....) RCD: (.....)

Original to the person ordering the work

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 12 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing:

Circuit number	Circuit description	CODES For Type of wiring		Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device			RCD		Circuit impedances (Ω)					Insulation resistance			RCD operating time (ms)	Test buttons								
		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit				(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Ring final circuits only (measured end to end)				All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)	Polarity	Max. measured earth fault loop impedance, Z _s (Ω)	RCD	AFDD
		Live (mm ²)	cpc (mm ²)				Max. disconnection time (BS 7671) (s)	Type	Rating	Short-circuit capacity	(Line) r ₁	(Neutral) r _n	(cpc) r ₂							(R ₁ +R ₂)	R ₂											
1L1	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.14									
1L2	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.15									
1L3	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.13									
2L1	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.14									
2L2	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.15									
2L3	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.12									
3L1	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.13									
3L2	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.12									
3L3	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.11									
4L1	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.12									
4L2	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.12									
4L3	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.11									
5L1	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.11									
5L2	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.16									
5L3	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.14									
6L1	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.11									
6L2	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.16									
6L3	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.14									
7L1	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.13									
7L2	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.16									

DISTRIBUTION BOARD (DB) DETAILS (to be completed in every case)
 DB designation: DB/W/COMMS/LG
 Location of DB: LOWER GROUND FLOOR COMMS
TESTED BY Name (capitals): GARY BARDRICK
 Signature:
 Position: APPROVED ELECTRICIAN
 Date: 22/01/2019

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION
 Supply to DB is from: (MCCB 3) Nominal voltage: (400) V No. of phases: (3)
 Overcurrent protection device for the distribution circuit Type: (BS EN) Rating: (100) A
 Associated RCD (if any) Type: (BS EN 60947-2) No. of poles: (3) I_{Δn} () mA Operating time: () ms
 Characteristics at this DB Confirmation of supply polarity: (Yes) Phase sequence confirmed (where appropriate): Z_s (0.11) Ω I_{Δf} (3.28) kA

TEST INSTRUMENTS (enter serial number against each instrument used)
 Multi-function: (101217148) Continuity: ()
 Insulation resistance: () Earth fault loop impedance: ()
 Earth electrode resistance: () RCD: ()

Original to the person ordering the work

CONTINUATION SHEET:
ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing:

Circuit number	Circuit description	CODES For Type of wiring		Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD	Circuit impedances (Ω)					Insulation resistance			RCD operating time	Test buttons									
		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit				(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)	Polarity	Max. measured earth fault loop impedance, Z _s (Ω)	RCD	AFDD	
		Live (mm ²)	cpc (mm ²)				Max. disconnection time (BS 7671) (s)	(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ +R ₂)	R ₂																					
8L1	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.13										
8L2	32A COMMANDO SOCKET	G	B	1	5	5	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.16										
8L3	32A COMMANDO SOCKET	G	B	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.15										
9L1	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.14										
9L2	GENERAL POWER - DADO SOCKETS	G/E	B	5	4	4	0.4	60898	MCCB	C	32	10	0.68	0.28	0.28	0.28	0.15		LIM	LIM	500	✓	0.23										
9L3	LIGHTING	B	B	6	2.5	2.5	0.4	60898	MCCB	C	10	10	2.18				0.50		LIM	LIM	500	✓	0.68										
10L1	32A COMMANDO SOCKET	G	F	1	4	4	0.4	60898	MCCB	C	32	10	0.68				LIM		LIM	LIM	LIM	✓	0.14										
10L2	SECURITY PANEL	D	B	1	4	4	0.4	60898	MCCB	C	20	10	1.09				0.01		LIM	LIM	500	✓	0.13										
10L3	SPARE																																
11L1	SPARE																																
11L2	SPARE																																
11L3	SPARE																																
12L1	SPARE																																
12L2	SPARE																																
12L3	SPARE																																

DISTRIBUTION BOARD (DB) DETAILS DB designation: DB/W/COMMS/LG **TESTED BY** Name (capitals): GARY BARDRICK Position: APPROVED ELECTRICIAN
 (to be completed in every case) Location of DB: LOWER GROUND FLOOR COMMS Signature: Date: 22/01/2019

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION
 Supply to DB is from: (MCCB 3) Nominal voltage: (400) V No. of phases: (3)
 Overcurrent protection device for the distribution circuit Type: (BS EN) Rating: (100) A
 Associated RCD (if any) Type: (BS EN 60947-2) No. of poles: (3) I_{Δn} (.....) mA Operating time: (.....) ms
 Characteristics at this DB Confirmation of supply polarity: (Yes.....) Phase sequence confirmed (where appropriate): True Z_s (0.11) Ω Z_f (3.28) kA

TEST INSTRUMENTS
 (enter serial number against each instrument used)
 Multi-function: (101217148) Continuity: (.....)
 Insulation resistance: (.....) Earth fault loop impedance: (.....)
 Earth electrode resistance: (.....) RCD: (.....)

Original to the person ordering the work



WEBSTER THOMAS ELECTRICAL LTD

Electrical Contracting Engineers

UNIT 7, CASTLE VIEW BUSINESS ESTATE, GAS HOUSE ROAD, ROCHESTER, KENT. ME11PB
Tel: 01634 818074

106181

IPR18

ELECTRICAL INSTALLATION CONDITION REPORT

ADDITIONAL NOTES

(This area is intentionally left blank for additional notes.)

(see additional page No. N/A)

Original to the person ordering the work

NOTES FOR RECIPIENT

THIS CONDITION REPORT IS AN IMPORTANT AND VALUABLE DOCUMENT WHICH SHOULD BE RETAINED FOR FUTURE USE

The purpose of periodic inspection is to determine, so far as is reasonably practicable, whether an electrical installation is in a satisfactory condition for continued service. This report provides an assessment of the condition of the electrical installation identified overleaf at the time it was inspected and tested, taking into account the stated extent of the installation and the limitations of the inspection and testing.

This report has been issued in accordance with the national standard for the safety of electrical installations, BS 7671: 2018 – Requirements for Electrical Installations.

The report identifies any damage, deterioration, defects and/or conditions found by the inspector which may give rise to danger (see PART 6), together with any items for which improvement is recommended.

If you were the person ordering this report, but not the user of the installation, you should pass this report, or a full copy of it including these notes, the schedules and additional pages (if any), immediately to the user.

This report should be retained in a safe place and shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this report will provide the new user with an assessment of the condition of the electrical installation at the time the periodic inspection was carried out.

Where the installation incorporates a residual current device (RCD) there should be a notice at or near the device stating that it should be tested every six months. For safety reasons it is important that this instruction is followed.

For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. NICEIC* recommends that you engage the services of an NICEIC Approved Contractor for the inspection.

The recommended date by which the next inspection should be carried out is stated in PART 5 of this report. There should also be a notice at or near the main switchboard or distribution board/consumer unit indicating when the next inspection of the installation is due.

Only an NICEIC Approved Contractor or Conforming Body is authorised to issue this NICEIC Electrical Installation Condition Report. You should have received the report marked 'Original' and the Approved Contractor should have retained the report marked 'Duplicate'.

This report form is intended to be issued only for the purpose of reporting on the condition of an existing electrical installation and must not be issued to certify new electrical installation work including the replacement of a distribution board or consumer unit.

The report consists of at least six numbered pages. Additional numbered pages may have been provided to permit further relevant information relating to the installation to be recorded. For installations having more than one distribution board or more circuits than can be recorded on PART 12, one or more additional Schedules of Circuit Details and Test Results should form part of the report. The report is invalid if any of the schedules identified in PART 10 are missing. The report has a printed seven-digit serial number, which is traceable to the Approved Contractor to which it was supplied by NICEIC.

PART 7 (Details and limitations) should identify fully the extent of the installation covered by this report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.

Operational limitations may have been encountered during the inspection such as inability to gain access to parts of the installation or to an item of equipment. The inspector should have noted any such limitations in PART 7. It should be noted that the greater the limitations applying to a report, the less its value from the safety aspect.

A declaration should have been given by the inspector in PART 4 of the report. The declaration must reflect the statement given in PART 3, which summarises the observations and recommendations made in PART 6. Where one or more observations have been made in PART 6, the Classification code given to each by the inspector indicates the degree of urgency with which remedial action needs to be taken to restore the installation to a safe working condition.

Where the inspector has indicated an observation as code C1 (danger present) the safety of those using the installation is at risk. Wherever practicable, items classified as (C1) should be made safe on discovery, and it is recommended that a skilled person(s) competent in electrical installation work undertakes the necessary remedial work immediately.

Where the inspector has indicated an observation as code C2 (potentially dangerous) the safety of those using the installation may be at risk, and it is recommended that a skilled person(s) competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.

Where the inspector has indicated that an item requires further investigation (FI), the investigation should be carried out without delay to determine whether danger or potential danger exists. For further guidance on the Classification codes, please see the reverse of page 2.

Where the installation can be supplied by more than one source, such as the public supply and a standby generator or microgenerator, this should be identified in PART 8 Supply Characteristics and Earthing Arrangements, and the Schedules of Circuit Details and Test Results (PART 12) compiled accordingly.

Where inadequacies in the intake equipment have been observed (Item 1 of PART 10), the person ordering the inspection should inform the distributor and/or supplier as appropriate.

Should the person ordering this report have reason to believe that it does not reasonably reflect the condition of the electrical installation reported on, that person should in the first instance raise the specific concerns in writing with the Approved Contractor. If the concerns remain unresolved, the person ordering this report may make a formal complaint to NICEIC, for which purpose a complaint form is available on request.

The complaints procedure offered by NICEIC is subject to certain terms and conditions, full details of which are available upon application. NICEIC does not investigate complaints relating to the operational performance of electrical installations (such as lighting levels), or to contractual or commercial issues (such as time or cost).

** NICEIC is operated by Certsure LLP, a partnership between the Electrical Contractors' Association and the charity, Electrical Safety First. NICEIC maintains and publishes registers of electrical contractors that it has assessed against particular scheme requirements (including the technical standard of electrical work).*

For further information about electrical safety and how NICEIC can help you,
visit www.niceic.com

GUIDANCE FOR RECIPIENTS ON THE CLASSIFICATION CODES

Only one Classification code should be given for each recorded Observation

Classification code C1 (Danger present)

Where an observation has been given a Classification code C1, the safety of those using the installation is at risk and immediate remedial action is required.

The person responsible for the maintenance of the installation is advised to take action without delay to remedy the observed deficiency in the installation, or to take other appropriate action (such as switching off and isolating the affected part(s) of the installation) to remove the danger. The NICEIC Approved Contractor issuing this report will be able to provide further advice.

NICEIC makes available 'Electrical Danger Notification' forms to enable inspectors to record, and then to communicate to the person ordering the report, any dangerous condition discovered.

Classification code C2 (Potentially dangerous)

Classification code C2 indicates that, whilst those using the installation may not be at immediate risk, urgent remedial action is required to remove potential danger. The NICEIC Approved Contractor issuing this report will be able to provide further advice.

It is important to note that the recommendation given at PART 5 of this report (Next Inspection) for the maximum interval until the next inspection is conditional upon all items which have been given a Classification code C1 and code C2 being remedied immediately and as a matter of urgency, respectively.

It would not be reasonable for the inspector to indicate that the installation is in a satisfactory condition if any observation in this report has been given a code C1 or code C2 classification.

Classification code C3 (Improvement recommended)

Where an observation has been given a Classification code C3, the inspection and/or testing has revealed a non-compliance with the current safety standard which, whilst not presenting immediate or potential danger, would result in a significant safety improvement if remedied. Careful consideration should be given to the safety benefits of improving these aspects of the installation. The NICEIC Approved Contractor issuing this report will be able to provide further advice.

Code FI (Further investigation required without delay)

It should usually be possible for the inspector to attribute a Classification code to each observation without indicating a need for further investigation.

However, where 'FI' has been entered against an observation the inspector considers that further investigation of that observation is likely to reveal danger or potential danger that, due to the agreed extent or limitations of the inspection and/or testing, could not be fully identified at the time.

It would not be appropriate for the inspector to indicate that the installation is in a satisfactory condition if there is reasonable doubt as to whether danger or potential danger exists. Consequently, where the inspector has indicated 'Further investigation required without delay' (FI) the overall assessment of the installation (PART 3) should be marked as 'Unsatisfactory'.

If the inspector has indicated that an observation requires further investigation without delay, the person ordering this report is advised to arrange for the NICEIC Approved Contractor issuing the report (or another skilled person or persons competent in such work) to undertake further examination of that aspect of the installation as a matter of urgency, to determine whether or not danger or potential danger exists.

Further information

Further information on the application of Classification codes, primarily aimed at inspectors but of possible interest to persons ordering condition reports, can be found in Electrical Safety First's Best Practice Guide No 4 Electrical installation condition reporting: Classification Codes for domestic and similar electrical installations. The guide can be viewed or downloaded free of charge from www.electricalsafetyfirst.org.uk

For further information about electrical safety and how NICEIC can help you, visit www.niceic.com



WEBSTER THOMAS ELECTRICAL LTD

Electrical Contracting Engineers

UNIT 7, CASTLE VIEW BUSINESS ESTATE, GAS HOUSE ROAD, ROCHESTER, KENT. ME11PB
Tel: 01634 818074

106181

IPR18

**CONTINUATION SHEET:
ELECTRICAL INSTALLATION CONDITION REPORT**

AGREED LIMITATIONS INCLUDING THE REASONS, IF ANY, ON THE INSPECTION AND TESTING - CONTINUED

NO ACCESS TO MAIN INCOMING SUPPLYING MCCB CHAMBERS
FCU IN RECEPTION DB/SP/REC/1L1 & DB/SP/REC/2L1 UNTRACEABLE
DB/MECH/2/11L1 SERVREY EXTRACT UNTRACEABLE
DB/MECH/2/11L2 W/C EXTRACT UNTRACEABLE
DB/SP/ROOF/2L1 UPRIGHT FRIDGE 1 UNTRACEABLE
DB/LT/REC/4L1 RECEPTION LIGHTING. NO TESTING POINT COULD BE FOUND (LED LIGHTING)

(see additional page No. N/A)

Original to the person ordering the work)