




# Asbestos Survey Report

Temple Court  
13a Cathedral Road  
Cardiff

31st October 2014

## Results and Analysis

Client	The Office UK				
Survey Address	13a Cathedral Road, Cardiff, CF11 9HA				
Building	Temple Court				
Location	External, Roofing and fascia tiles				
Survey Ref	8177/141031				
Sample Ref	No Sample Taken				
<b>Photo Details</b>					
<b>Risk Matrix</b>					
Asbestos Type	Chrysotile (Identified)	1	Product/Use	Asbestos-Reinforced Composites	1
Condition	Good Condition	0	Treatment	Composite Materials	0
Identified Risk	Very Low	2	Action	Action D	
Extent	As Seen				
Accessibility	Easy Access				
Remarks	<b>No sign of deterioration since last survey dated 24/06/2008.</b>				

## 8 Asbestos Register

No samples were taken.

Sample Ref	Location	Asbestos Content	Asbestos Product	Material Description	Condition	Score	Action	Comments	Date Signature
Sample Not Taken	External	Chrysotile	Asbestos-Reinforced Composites	Roofing and fascia tiles	Good Condition	2	Action D	No sign of deterioration since last survey dated 24/06/2008	