

ELECTRICAL INSTALLATION CERTIFICATE

ICN0000146 - Master

[BS 7671:2008 as amended]



GEORGE E BUXTON

Details of the Client

Client/Address Area , The Old post Office, 3 Station Road, Egham, Surrey, TW209LA

Details of the Installation

Address Tudor Street, 22 Tudor Street, London, EC4Y0AY

Extent of the installation covered by this certificate WHOLE INSTALLATION

The installation is:

New An Addition N/AAn Alteration N/A

Design

We being the person(s) responsible for the design of the electrical installation (as indicated by our signature(s) below), particulars of which are described above, have exercised reasonable skill and care when carrying out the design hereby CERTIFY that the design work for which We have been responsible is, to the best of our knowledge and belief in accordance with BS 7671 amended to July 2015 (date) except for the departures, if any detailed as follows:

Details of departures from BS 7671, as amended (Regulations 120.3, 133.5) None

Details of permitted exceptions (Regulations 411.3.3): N/A Where applicable, a suitable risk assessment(s) must be attached to this Certificate: N/A Number of pages: N/A

The extent of liability of the signatory or signatories is limited to the work described above as the subject of this certificate.

For the DESIGN of the installation:

Signature: Date: 08/01/2019 Name (CAPITALS): KEVIN WOODING Designer 1

Signature: Date: 08/01/2019 Name (CAPITALS): Kevin Myers Designer 2 **

**(where there is divided responsibility for the design)

Construction

We being the person(s) responsible for the construction of the electrical installation (as indicated by our signature(s) below), particulars of which are described above, have exercised reasonable skill and care when carrying out the construction hereby CERTIFY that the construction work for which We have been responsible is, to the best of our knowledge and belief in accordance with BS 7671 amended to July 2015 (date) except for the departures, if any detailed as follows:

Details of departures from BS 7671, as amended (Regulations 120.3, 133.5) None

The extent of liability of the signatory is limited to the work described above as the subject of this certificate.

For the CONSTRUCTION of the installation:

Signature: Date: 13/05/2019 Name (CAPITALS): Tom Stagg Constructor

Inspection and Testing

We being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by our signature(s) below), particulars of which are described above, have exercised reasonable skill and care when carrying out the inspection and testing hereby CERTIFY that the work for which We have been responsible is, to the best of our knowledge and belief in accordance with BS 7671 amended to July 2015 (date) except for the departures, if any detailed as follows:

Details of departures from BS 7671, as amended (Regulations 120.3, 133.5) None

The extent of liability of the signatory is limited to the work described above as the subject of this certificate.

For the INSPECTION AND TESTING of the installation:

Reviewed by

Signature: Date: 13/05/2019 Signature: Date: 22/05/2019
Name (CAPITALS): Brian Stanford Inspector Name (CAPITALS): Anthony Wilkinson Qualified Supervisor

DESIGN (1)		Organisation	George E Buxton Ltd		NICEIC Enrolment Number	111970	
Address	2 Twyford Business Centre London Road Bishops Stortford Hertfordshire CM23 3YT			Tel	01279 659911		
					Branch No.(If Applicable)	N/A	
DESIGN (2)	Organisation	George E Buxton Ltd		NICEIC Enrolment Number	111970		
Address	2 Twyford Business Centre London Road Bishops Stortford Hertfordshire CM23 3YT			Tel	01279 659911		
					Branch No.(If Applicable)	N/A	
CONSTRUCTION	Organisation	George E Buxton Ltd		NICEIC Enrolment Number	111970		
Address	2 Twyford Business Centre London Road Bishops Stortford Hertfordshire CM23 3YT			Tel	01279 659911		
					Branch No.(If Applicable)	N/A	
INSPECTION AND TESTING	Organisation	George E Buxton Ltd		NICEIC Enrolment Number	111970		
Address	2 Twyford Business Centre London Road Bishops Stortford Hertfordshire CM23 3YT			Tel	01279 659911		
					Branch No.(If Applicable)	N/A	
Supply Characteristics and Earthing Arrangements				Tick boxes and enter details, as appropriate			Characteristics of primary supply overcurrent protective Device(s)
System Type(s)	Number and Type of Live Conductors			Nature of Supply Parameters			BS(EN)
TN-S	<input checked="" type="checkbox"/>	a.c.	<input checked="" type="checkbox"/>	d.c.	N/A	Nominal Voltage	U 400 V
TN-C-S	N/A	1-Phase (2 wire)	N/A	1-Phase (3 wire)	N/A	Nominal frequency	f 50 Hz
TN-C	N/A	2-Phase (3 wire)	N/A	3 Pole	N/A	Prospective fault current	IpF 10 kA
TT	N/A	3-Phase (3 wire)	N/A	3-Phase (4 wire)	<input checked="" type="checkbox"/>	External loop impedance	Ze 0.02 Ω
IT	N/A	Other	N/A			Number of Sources	1
							Type gG
							Rated current 630 A
							Short circuit Capacity 80 kA
							Confirmation of Supply Polarity <input checked="" type="checkbox"/>
Particulars of Installation at the Origin							
Means of Earthing	Details of Installation Earth Electrode (where applicable)						
Distributor's facility	<input checked="" type="checkbox"/>	Type (eg rod(s), tape etc)	N/A		Location	N/A	
Installation earth electrode	N/A	Electrode resistance, R _A	N/A	Ω	Method of measurement	N/A	
Main Switch/ Switch-Fuse/ Circuit-Breaker/ RCD	Maximum Demand (Load)			Protective measure(s) against electric shock			
Type BS(EN)	60947-2	Voltage Rating	690 V	500 Amps	ADS		
No. of poles	4	Rated Current, I _n	630 A	Earthing and Protective Bonding Conductors			Bonding of extraneous conductive parts (✓)
Supply Conductors material	Copper	RCD operating current, I _{an}	N/A mA	Earthing conductor	Main protective bonding conductors	Water installation pipes ✓	
Supply Conductors CSA	4x95 mm ²	RCD operating time at, I _{an}	N/A ms	Conductor material: Copper	Conductor material: Copper	Lightning Protection ✓	
		Rated time delay	N/A ms	Conductor csa: 50 mm ²	Conductor csa: 50 mm ²	Oil installation pipes N/A	
				Continuity/ connection verified N/A	Continuity/ connection verified N/A	Structural Steel ✓	
						Gas installation pipes ✓	
						Other	
Comments on Existing Installation							
In the case of an alteration or additions see Regulation 633 None							
Next Inspection							
We, the designer(s) RECOMMEND that this installation is further inspected and tested after an interval of not more than 5 Years or change of tenancy.							

Schedule of Items Inspected

Outcomes	Acceptable condition	✓	Not applicable	N/A	ICN0000146 - Master
----------	----------------------	---	----------------	-----	---------------------

Item No	Description	Outcome	Item No	Description		Outcome
1.0	CONDITION OF DISTRIBUTOR'S/SUPPLY INTAKE EQUIPMENT (the Distributor should be notified of any unsatisfactory equipment)		6.0	OTHER METHODS OF PROTECTION (insert location in box provided)		
1.1	Service cable	✓	6.1	Basic and fault protection	LOCATION	
1.2	Service head	✓	a)	SELV		✓
1.3	Distributor's earthing arrangement	✓	b)	PELV		N/A
1.4	Meter tails - Distributor/Consumer	✓	c)	Double insulation/Reinforced insulation		N/A
1.5	Metering equipment	✓	d)	Electrical separation for one item of equipment		N/A
1.6	Isolator	✓	6.2	Fault protection	LOCATION	
2.0	PARALLEL OR SWITCHED ALTERNATIVE SOURCES OF SUPPLY		a)	Non-conducting location/Earth-free local equipotential bonding**		N/A
2.1	Presence of adequate arrangements where generator to operate as a switched alternative	✓	b)	Electrical separation for more than one item of equipment**		N/A
2.1 a)	Dedicated earthing arrangement independent of that of the public supply	✓	7.0	DISTRIBUTION EQUIPMENT		
2.2	Presence of adequate arrangements where generator to operate in parallel with public supply system		7.1	Adequacy of working space/accessibility		✓
2.2 a)	Correct connection of generator in parallel	✓	7.2	Security of fixing		✓
2.2 b)	Compatibility of characteristics of means of generation	✓	7.3	Insulation of live parts not damaged during erection		✓
2.2 c)	Means to provide automatic disconnection of generator in the event of loss of public supply system or voltage or frequency deviation beyond declared values	✓	7.4	Adequacy / security of barriers		✓
2.2 d)	Means to prevent connection of generator in the event of loss of public supply system or voltage or frequency deviation beyond declared values	✓	7.5	Suitability of enclosures for IP and fire ratings		✓
2.2 e)	Means to isolate generator from the public supply system	✓	7.6	Enclosures not damaged during installation		✓
2.3	Presence of alternative/additional supply warning notices at:		7.7	Presence and effectiveness of obstacles		✓
2.3 a)	The origin	✓	7.8	Presence of main switch(es), linked where required		✓
2.3 b)	The meter position, if remote from origin	✓	7.9	Operation of main switch(es) (functional check)		✓
2.3 c)	The consumer unit/distribution board to which the alternative/additional sources are connected	✓	7.10	Operation of circuit-breakers and RCDs to prove functionality		✓
2.3 d)	All points of isolation of ALL sources of supply	✓	7.11	RCD(s) provided for fault protection, where specified RCD(s) provided for fault protection, where specified		✓
3.0	AUTOMATIC DISCONNECTION OF SUPPLY		7.12	RCD(s) provided for protection against fire		✓
3.1	Presence and adequacy of protective earthing/bonding arrangements as follows:		7.13	RCD(s) provided for additional protection, where specified		✓
3.1 a)	Distributor's earthing arrangement or installation earth electrode arrangement	N/A	7.14	Confirmation overvoltage protection (SPDs) provided where specified		✓
3.1 b)	Earthing conductor and connections	✓	7.15	Confirmation of indication that SPD is functional		✓
3.1 c)	Main protective bonding conductors and connections	✓	7.16	Presence of RCD quarterly test notice at or near the origin		✓
3.1 d)	Earthing/bonding labels at all appropriate locations	✓	7.17	Presence of diagrams, charts or schedules at or near each distribution board, where required		✓
3.2	Accessibility of:		7.18	Presence of non-standard (mixed) cable colour warning notice at or near the appropriate distribution board, where required		✓
3.2 a)	Earthing conductor connections	✓	7.19	Presence of next inspection recommendation label		✓
3.2 b)	All protective bonding connections	✓	7.20	Presence of other required labelling		✓
3.3	FELV - requirements satisfied	N/A	7.21	Selection of protective device(s) and base(s); correct type and rating		✓
3.4	Reduced low voltage - requirements satisfied	✓	7.22	Single-pole protective devices in line conductor only		✓
4.0	BASIC PROTECTION		7.23	Protection against mechanical damage where cables enter equipment		✓
4.1	Presence and adequacy of protective measures to provide basic protection		7.24	Protection against electromagnetic effects where cables enter ferromagnetic enclosures		✓
4.1 a)	Insulation of live parts	✓	7.25	Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure		✓
4.1 b)	Barriers or enclosures	✓				
4.1 c)	Obstacles	N/A				
4.1 d)	Placing out of reach	N/A				
5.0	ADDITIONAL PROTECTION					
5.1	The presence and effectiveness of additional protection methods used, as follows:					
5.1 a)	RCDs not exceeding 30mA operating current	✓				
5.1 b)	Supplementary bonding	✓				

Schedule of Items Inspected

ICN0000146 - Master

Inspected By

Name: Tom Stagg

Date: 20/05/2019

Signature:

三

Schedule of Additional Records (See attached schedule)

The attached Schedules are part of this document and this Certificate is valid only when they are attached to it.

8 - 80 (even) Schedules of Inspections and 9 - 81 (odd) Schedules of Test Results

Board Details

TO BE COMPLETED IN EVERY CASE		ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION					
Location of distribution board	BASEMENT LV SWITCH ROOM	Supply to distribution board is from	N/A	Associated RCD (if any)			
Distribution board designation	LV 1 SWITCH	No of phases	N/A	Nominal Voltage	N/A	V	BS(EN) N/A
		Overcurrent protective device for the distribution circuit		RCD No of poles	N/A		RCD rating, I _{Δn} mA
		Type BS(EN)	N/A	Rating A	N/A		N/A mA

Circuit Details

Circuit number and line	Circuit designation	Type of wiring	Reference method	No of points served	Circuit conductors csa		Max. permitted disconnection time s	Overcurrent protective device				RCD	Max. permitted Zs
					Live mm ²	cpc mm ²		BS(EN)	Type	Rating A	Short circuit capacity kA		
1/TP	Way Not Available	-	-	-	-	-	-	-	-	-	-	-	-
2/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
3/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
4/TP	Sub Mains(DB/LLB/MECH)	G	E	1	25	70	5	60947-2 MCCB		100	50	N/A	0.2
5/TP	Sub Mains(DB LIFT 1/2 & 3)	G	E	1	25	70	5	60947-2 MCCB		100	50	N/A	0.2
6/TP	Sub Mains(DB/COMMS)	G	E	1	25	70	5	60947-2 MCCB		100	50	N/A	0.2
7/TP	Sub Mains(DB/LL/B)	G	E	1	25	70	5	60947-2 MCCB		100	50	N/A	0.2
8/TP	Sub Mains(DB/LL/2)	G	E	1	25	70	5	60947-2 MCCB		100	50	N/A	0.2
9/TP	Sub Mains(DB/LL/4)	G	E	1	25	70	5	60947-2 MCCB		100	50	N/A	0.2
10/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
11/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
12/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
13/L1	FIRE ALARM PANEL	O	E	1	4	4	0.4	60947-2 MCCB		16	50	N/A	1
13/L2	Way Not Available	-	-	-	-	-	-	-	-	-	-	-	-
13/L3	Way Not Available	-	-	-	-	-	-	-	-	-	-	-	-
14/TP	Sub Mains(DB/LLB/AHU)	G	E	1	35	80	5	60947-2 MCCB		125	50	N/A	0.15
15/TP	Sub Mains(DB/LLR)	G	E	1	70	138	5	60947-2 MCCB		160	50	N/A	0.14
16/TP	Sub Mains(DB/LLR/MECH)	G	E	1	95	160	5	60947-2 MCCB		250	50	N/A	0.07
17/TP	Sub Mains(RISING BUSBAR)	G	E	7	150	230	5	60947-2 MCCB		400	50	N/A	0.09
18/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
19/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-

Wiring Code

A	B	C	D	E	F	G	H	O
Thermoplastic insulated/sheathed cables	Thermoplastic cables in metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic/SWA cables	Thermosetting/SWA cables	Mineral-insulated cables	Other

Board Tests												
ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION								TEST INSTRUMENTS (SERIAL NUMBERS) USED				
Zs	N/A	Ω	Operating times of associated RCD (if any)	At $I \Delta n$	N/A	ms	Earth fault loop impedance	0706070380	RCD	0706070380		
Ipf	N/A	kA		At $5I \Delta n$ (if applicable)	N/A	ms	Insulation resistance	0706070380	Multi-function	N/A		
Confirmation of Supply polarity	<input checked="" type="checkbox"/>	Phase sequence confirmed (where appropriate)	<input checked="" type="checkbox"/>				Continuity	0706070380	Other	N/A		
Circuit Tests												
Circuit number and line	Circuit impedances				Insulation resistance				Polarity	RCD		
	Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)		Line/Line	Line/Neutral	Line/Earth		Earth/Neutral	Operating times	
	r_1 (Line)	r_n (Neutral)	r_2 (cpc)	$r_1 + r_2$	r_2						MΩ	MΩ
1/TP	-	-	-	-	-	-	-	-	-	-	-	
2/TP	-	-	-	-	-	-	-	-	-	-	-	
3/TP	-	-	-	-	-	-	-	-	-	-	-	
4/TP	N/A	N/A	N/A	0.09	N/A	>499	>499	>499	>499	✓	0.06	
5/TP	N/A	N/A	N/A	0.13	N/A	>499	>499	>499	>499	✓	0.16	
6/TP	N/A	N/A	N/A	0.10	N/A	>499	>499	>499	>499	✓	0.14	
7/TP	N/A	N/A	N/A	0.02	N/A	>499	>499	>499	>499	✓	0.05	
8/TP	N/A	N/A	N/A	0.08	N/A	>499	>499	>499	>499	✓	0.06	
9/TP	N/A	N/A	N/A	0.07	N/A	>499	>499	>499	>499	✓	0.06	
10/TP	-	-	-	-	-	-	-	-	-	-	-	
11/TP	-	-	-	-	-	-	-	-	-	-	-	
12/TP	-	-	-	-	-	-	-	-	-	-	-	
13/L1	N/A	N/A	N/A	0.34	N/A	N/A	>299	>299	>299	✓	0.26	
13/L2	-	-	-	-	-	-	-	-	-	-	-	
13/L3	-	-	-	-	-	-	-	-	-	-	-	
14/TP	N/A	N/A	N/A	0.10	N/A	>499	>499	>499	>499	✓	0.08	
15/TP	N/A	N/A	N/A	0.08	N/A	>499	>499	>499	>499	✓	0.06	
16/TP	N/A	N/A	N/A	0.05	N/A	>499	>499	>499	>499	✓	0.06	
17/TP	N/A	N/A	N/A	0.10	N/A	>499	>499	>499	>499	✓	0.03	
18/TP	-	-	-	-	-	-	-	-	-	-	-	
19/TP	-	-	-	-	-	-	-	-	-	-	-	

Tested By											
Signature					Position	Qualifying Supervisor					
Name	Anthony Wilkinson				Date of testing	22/02/2019					

Board Details

TO BE COMPLETED IN EVERY CASE		ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION							
Location of distribution board	ELECTRICAL RISER	Supply to distribution board is from	SubMains(LV 1 SWITCH , 17/TP)					Associated RCD (if any)	
Distribution board designation	RISING BUSBAR	No of phases	3	Nominal Voltage	400	V	BS(EN) N/A	RCD No of poles	N/A
		Overcurrent protective device for the distribution circuit	Type BS(EN) 60947-2 MCCB	Rating	400	A	RCD rating, IΔn N/A mA		

Circuit Details

Circuit number and line	Circuit designation	Type of wiring	Reference method	No of points served	Circuit conductors csa		Max. permitted disconnection time s	Overcurrent protective device				RCD	Max. permitted Zs
					Live mm ²	cpc mm ²		BS(EN)	Type	Rating A	Short circuit capacity kA		
1/TP	Sub Mains(DB/B/P,DB/B/L)	B	B	1	25	16	5	60947-2 MCCB		100	36	N/A	0.22
2/TP	Sub Mains(DB/G/P,DB/G/L)	B	B	1	25	16	5	60947-2 MCCB		100	36	N/A	0.22
3/TP	Sub Mains(DB/1/P,DB/1/L)	B	B	1	25	16	5	60947-2 MCCB		100	36	N/A	0.22
4/TP	Sub Mains(DB/2/P,DB/2/L)	B	B	1	25	16	5	60947-2 MCCB		100	36	N/A	0.22
5/TP	Sub Mains(DB/3/P,DB/3/L)	B	B	1	25	16	5	60947-2 MCCB		100	36	N/A	0.22
6/TP	Sub Mains(DB/4/P,DB/4/L)	B	B	1	25	16	5	60947-2 MCCB		100	36	N/A	0.22
7/TP	Sub Mains(DB/5/P,DB/5/L)	B	B	1	25	16	5	60947-2 MCCB		100	36	N/A	0.22
8/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
9/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
10/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
11/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
12/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
13/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
14/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
15/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
16/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
17/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
18/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
19/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
20/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
21/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
22/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-

Wiring Code

A	B	C	D	E	F	G	H	O
Thermoplastic insulated/sheathed cables	Thermoplastic cables in metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic/SWA cables	Thermosetting/SWA cables	Mineral-insulated cables	Other

Board Tests											
ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION								TEST INSTRUMENTS (SERIAL NUMBERS) USED			
Z _s	0.03	Ω	Operating times of associated RCD (if any)	At I Δ n	N/A	ms	Earth fault loop impedance	0706070380	RCD	0706070380	
I _{pf}	10	kA		At 5I Δ n (if applicable)	N/A	ms	Insulation resistance	0706070380	Multi-function	N/A	
Confirmation of Supply polarity	<input checked="" type="checkbox"/>	Phase sequence confirmed (where appropriate)		<input checked="" type="checkbox"/>			Continuity	0706070380	Other	N/A	

Circuit Tests														
Circuit number and line	Circuit impedances					Insulation resistance				Polarity	Maximum measured earth fault loop impedance	RCD		
	Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)		Line/ Line	Line/ Neutral	Line/ Earth	Earth/ Neutral			Operating times		
	r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	R ₁ + R ₂	R ₂							MΩ	MΩ	MΩ
1/TP	N/A	N/A	N/A	0.01	N/A	>499	>499	>499	>499	✓	0.03	N/A	N/A	N/A
2/TP	N/A	N/A	N/A	0.01	N/A	>499	>499	>499	>499	✓	0.03	N/A	N/A	N/A
3/TP	N/A	N/A	N/A	0.01	N/A	>499	>499	>499	>499	✓	0.03	N/A	N/A	N/A
4/TP	N/A	N/A	N/A	0.01	N/A	>499	>499	>499	>499	✓	0.03	N/A	N/A	N/A
5/TP	N/A	N/A	N/A	0.01	N/A	>499	>499	>499	>499	✓	0.03	N/A	N/A	N/A
6/TP	N/A	N/A	N/A	0.01	N/A	>499	>499	>499	<499	✓	0.03	N/A	N/A	N/A
7/TP	N/A	N/A	N/A	0.01	N/A	>499	>499	>499	>499	✓	0.03	N/A	N/A	N/A
8/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-
9/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-
10/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-
11/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-
12/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-
13/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-
14/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-
15/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-
16/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-
17/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-
18/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-
19/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-
21/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-
22/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By											
Signature					Position	Qualifying Supervisor					
Name	Anthony Wilkinson				Date of testing	25/02/2019					

SCHEDULE OF CIRCUIT DETAILS FOR THE INSTALLATION

ICN0000146 - Master

Board Details

TO BE COMPLETED IN EVERY CASE		ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION							
Location of distribution board	BASEMENT ELECTRICAL RISER	Supply to distribution board is from	SubMains(RISING BUSBAR, 1/TP)					Associated RCD (if any)	
Distribution board designation	DB/B/L	No of phases	3	Nominal Voltage	400	V	BS(EN) N/A	RCD No of poles	N/A
		Overcurrent protective device for the distribution circuit					RCD rating, I _{Δ n} mA	RCD rating, I _{Δ n} mA	N/A
		Type BS(EN)	60947-2 MCCB	Rating A	100	A	N/A	N/A	mA

Circuit Details

Circuit number and line	Circuit designation	Type of wiring	Reference method	No of points served	Circuit conductors csa		Max. permitted disconnection time s	Overcurrent protective device				RCD	Max. permitted Zs
					Live mm ²	cpc mm ²		BS(EN)	Type	Rating A	Short circuit capacity kA		
1/L1	LIGHTING HARDWIRED LCM 2	O	E	15	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	2.19
1/L2	LIGHTING HARDWIRED LCM 3	O	E	18	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	2.19
1/L3	LIGHTING 20 PERSON MEETING ROOM	O	E	2	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	2.19
2/L1	LIGHTING INTERACTIVE ROOM	O	E	1	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	2.19
2/L2	LIGHTING HARDWIRED LCM 5	O	E	22	2.5	2.5	0.4	60898 MCB	B	10	10	N/A	4.37
2/L3	BUS LOUNGE NEON	O	E	1	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	2.19
3/L1	ARCADE NEON	O	E	1	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	2.19
3/L2	5A SOCKETS	O	E	2	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	2.19
3/L3	AREA CONTROLLER	O	E	1	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	2.19
4/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
4/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
4/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
5/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
5/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
5/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
6/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
6/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
6/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-

Wiring Code

A	B	C	D	E	F	G	H	O
Thermoplastic insulated/ sheathed cables	Thermoplastic cables in metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic SWA cables	Thermosetting/ SWA cables	Mineral-insulated cables	Other

Board Tests											
ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION								TEST INSTRUMENTS (SERIAL NUMBERS) USED			
Zs	0.03	Ω	Operating times of associated RCD (if any)	At $I \Delta n$	N/A	ms	Earth fault loop impedance	101333008	RCD	101333008	
Ipf	9.3	kA		At $5I \Delta n$ (if applicable)	N/A	ms	Insulation resistance	101333008	Multi-function	N/A	
Confirmation of Supply polarity	<input checked="" type="checkbox"/>	Phase sequence confirmed (where appropriate)		<input checked="" type="checkbox"/>			Continuity	101333008	Other	N/A	

Circuit Tests																	
Circuit number and line	Circuit impedances Ω					Insulation resistance				Polarity	Maximum measured earth fault loop impedance	RCD					
	Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)		Line/Line	Line/Neutral	Line/Earth	Earth/Neutral			Operating times					
	r_1 (Line)	r_n (Neutral)	r_2 (cpc)	$R_1 + R_2$	R_2							ΜΩ	ΜΩ	ΜΩ	ΜΩ	At $I \Delta n$	At $5I \Delta n$
	1/L1	N/A	N/A	N/A	1.21							N/A	N/A	>299	>299	>299	<input checked="" type="checkbox"/>
1/L2	N/A	N/A	N/A	1.79	N/A	N/A	>299	>299	>299	<input checked="" type="checkbox"/>	1.88	N/A	N/A	N/A			
1/L3	N/A	N/A	N/A	0.16	N/A	N/A	>299	>299	>299	<input checked="" type="checkbox"/>	0.25	N/A	N/A	N/A			
2/L1	N/A	N/A	N/A	0.21	N/A	N/A	>299	>299	>299	<input checked="" type="checkbox"/>	0.30	N/A	N/A	N/A			
2/L2	N/A	N/A	N/A	2.88	N/A	N/A	>299	>299	>299	<input checked="" type="checkbox"/>	2.97	N/A	N/A	N/A			
2/L3	N/A	N/A	N/A	0.30	N/A	N/A	>299	>299	>299	<input checked="" type="checkbox"/>	0.39	N/A	N/A	N/A			
3/L1	N/A	N/A	N/A	0.47	N/A	N/A	>299	>299	>299	<input checked="" type="checkbox"/>	0.56	N/A	N/A	N/A			
3/L2	N/A	N/A	N/A	0.22	N/A	N/A	>299	>299	>299	<input checked="" type="checkbox"/>	0.33	N/A	N/A	N/A			
3/L3	N/A	N/A	N/A	0.02	N/A	N/A	>299	>299	>299	<input checked="" type="checkbox"/>	0.11	N/A	N/A	N/A			
4/L1	-	-	-	-	-	-	-	-	-	-	-	-	-				
4/L2	-	-	-	-	-	-	-	-	-	-	-	-	-				
4/L3	-	-	-	-	-	-	-	-	-	-	-	-	-				
5/L1	-	-	-	-	-	-	-	-	-	-	-	-	-				
5/L2	-	-	-	-	-	-	-	-	-	-	-	-	-				
5/L3	-	-	-	-	-	-	-	-	-	-	-	-	-				
6/L1	-	-	-	-	-	-	-	-	-	-	-	-	-				
6/L2	-	-	-	-	-	-	-	-	-	-	-	-	-				
6/L3	-	-	-	-	-	-	-	-	-	-	-	-	-				
Tested By																	
Signature						Position		Electrician									
Name	Brian Stanford					Date of testing		09/05/2019									

Board Details

TO BE COMPLETED IN EVERY CASE		ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION							
Location of distribution board	BASEMENT ELECTRICAL RISER	Supply to distribution board is from	SubMains(RISING BUSBAR, 1/TP)					Associated RCD (if any)	
Distribution board designation	DB/B/P	No of phases	3	Nominal Voltage	400	V	BS(EN) N/A	RCD No of poles	N/A
		Type	BS(EN) 60947-2 MCCB	Rating	100	A	RCD rating, $I_{\Delta n}$ mA	N/A	mA

Circuit Details

Circuit number and line	Circuit designation	Type of wiring	Reference method	No of points served	Circuit conductors csa		Max. permitted disconnection time s	Overcurrent protective device				RCD	Max. permitted Zs
					Live mm ²	cpc mm ²		BS(EN)	Type	Rating A	Short circuit capacity kA		
1/L1	GENERAL USE SOCKETS 1	O	C	3	4	4	0.4	61009 RCD/RCBO	C	32	10	30	0.68
1/L2	ARCADE MACHINE	O	E	4	4	4	0.4	61009 RCD/RCBO	C	32	10	30	0.68
1/L3	GENERAL USE SOCKETS 2	O	C	15	4	4	0.4	61009 RCD/RCBO	C	32	10	30	0.68
2/L1	GENERAL USE SOCKETS 3	O	C	9	4	4	0.4	61009 RCD/RCBO	C	32	10	30	0.68
2/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
2/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
3/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
3/L2	PHONE BOOTH - RADIAL	O	C	5	4	4	0.4	61009 RCD/RCBO	C	20	10	30	1.09
3/L3	AV POWER	O	E	7	4	4	0.4	61009 RCD/RCBO	C	32	10	30	0.68
4/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
4/L2	FAN COIL RING	O	E	3	4	4	0.4	60898 MCB	C	32	10	N/A	0.68
4/L3	FAN COIL RING	O	E	5	4	4	0.4	60898 MCB	C	32	10	N/A	0.68
5/L1	COFFEE MACHINE	G	C	1	4	4	0.4	61009 RCD/RCBO	C	32	10	30	0.68
5/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
5/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
6/L1	COFFEE BAR FRIDGE & BILLI TAP	O	C	2	4	4	0.4	61009 RCD/RCBO	C	32	10	30	0.68
6/L2	WASTE PUMP	O	C	1	4	4	0.4	60898 MCB	C	16	10	N/A	1.37
6/L3	CLEANERS SOCKETS	O	C	5	4	4	0.4	61009 RCD/RCBO	C	32	10	30	0.68
7/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
7/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
7/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
8/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
8/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
8/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-

Wiring Code

A	B	C	D	E	F	G	H	O
Thermoplastic insulated/sheathed cables	Thermoplastic cables in metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic SWA cables	Thermosetting/SWA cables	Mineral-insulated cables	Other

Board Tests														
ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION								TEST INSTRUMENTS (SERIAL NUMBERS) USED						
Zs	0.03	Ω	Operating times of associated RCD (if any)	At 1 Δn	N/A	ms	Earth fault loop impedance	101333008	RCD	101333008				
Ipf	9.3	mA		At 5I Δn (if applicable)	N/A	ms	Insulation resistance	101333008	Multi-function	N/A				
Confirmation of Supply polarity	<input checked="" type="checkbox"/>	Phase sequence confirmed (where appropriate)		<input checked="" type="checkbox"/>			Continuity	101333008	Other	N/A				
Circuit Tests														
Circuit number and line	Circuit impedances Ω				Insulation resistance				Polarity	RCD				
	Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)	Line/ Line	Line/ Neutral	Line/ Earth	Earth/ Neutral		Operating times				
	r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	R ₁ + R ₂	R ₂	MΩ	MΩ	MΩ		MΩ	At 1 Δn ms	At 5I Δn ms	Test button operation	
1/L1	0.34	0.33	0.22	0.13	N/A	N/A	>299	>299	>299	✓	0.38	28.8	28.9	✓
1/L2	0.27	0.27	0.19	0.09	N/A	N/A	>299	>299	>299	✓	0.19	28.9	28.9	✓
1/L3	0.56	0.56	0.27	0.17	N/A	N/A	>299	>299	>299	✓	0.20	28.9	29	✓
2/L1	0.31	0.31	0.19	0.09	N/A	N/A	>299	>299	>299	✓	0.14	29	29	✓
2/L2	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2/L3	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3/L1	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3/L2	N/A	N/A	N/A	0.14	N/A	N/A	>299	>299	>299	✓	0.24	28.9	28.9	✓
3/L3	0.33	0.33	0.10	0.07	N/A	N/A	>299	>299	>299	✓	0.17	28.7	29.2	✓
4/L1	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4/L2	0.33	0.34	0.21	0.12	N/A	N/A	>299	>299	>299	✓	0.17	N/A	N/A	N/A
4/L3	0.22	0.24	0.13	0.07	N/A	N/A	>299	>299	>299	✓	0.19	N/A	N/A	N/A
5/L1	N/A	N/A	N/A	0.10	N/A	N/A	>299	>299	>299	✓	0.19	29	29	✓
5/L2	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5/L3	-	-	-	-	-	-	-	-	-	-	-	-	-	-
6/L1	0.28	0.28	0.14	0.07	N/A	N/A	>299	>299	>299	✓	0.17	28.9	28.9	✓
6/L2	N/A	N/A	N/A	0.16	N/A	N/A	>299	>299	>299	✓	0.25	N/A	N/A	N/A
6/L3	0.47	0.40	0.23	0.17	N/A	N/A	>299	>299	>299	✓	0.16	38.9	28.9	✓
7/L1	-	-	-	-	-	-	-	-	-	-	-	-	-	-
7/L2	-	-	-	-	-	-	-	-	-	-	-	-	-	-
7/L3	-	-	-	-	-	-	-	-	-	-	-	-	-	-
8/L1	-	-	-	-	-	-	-	-	-	-	-	-	-	-
8/L2	-	-	-	-	-	-	-	-	-	-	-	-	-	-
8/L3	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Tested By														
Signature						Position		Electrician						
Name		Brian Stanford				Date of testing		09/05/2019						

SCHEDULE OF CIRCUIT DETAILS FOR THE INSTALLATION

ICN0000146 - Master

Board Details

TO BE COMPLETED IN EVERY CASE		ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION					
Location of distribution board	BASEMENT ELECTRICAL RISER	Supply to distribution board is from	SubMains(RISING BUSBAR, 1/TP)				Associated RCD (if any)
Distribution board designation	DB/B/P	No of phases	3	Nominal Voltage	400	V	BS(EN) N/A RCD No of poles N/A RCD rating, IΔn N/A mA

Circuit Details

Circuit number and line	Circuit designation	Type of wiring	Reference method	No of points served	Circuit conductors csa		Max. permitted disconnection time s	Overcurrent protective device				RCD	Max. permitted Zs
					Live mm ²	cpc mm ²		BS(EN)	Type	Rating A	Short circuit capacity kA	IΔn	
9/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
9/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
9/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
10/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
10/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
10/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
11/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
11/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
11/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
12/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
12/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
12/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
13/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
13/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
13/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
14/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
14/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
14/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
15/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
16/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
16/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
16/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-

Wiring Code

A	B	C	D	E	F	G	H	O
Thermoplastic insulated/sheathed cables	Thermoplastic cables in metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic/SWA cables	Thermosetting/SWA cables	Mineral-insulated cables	Other

Board Tests										
ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION								TEST INSTRUMENTS (SERIAL NUMBERS) USED		
Z _s	0.03	Ω	Operating times of associated RCD (if any)	At I _{Δn}	N/A	ms	Earth fault loop impedance	101333008	RCD	101333008
I _{pf}	9.3	kA		At 5I _{Δn} (if applicable)	N/A	ms	Insulation resistance	101333008	Multi-function	N/A
Confirmation of Supply polarity	<input checked="" type="checkbox"/>	Phase sequence confirmed (where appropriate)		<input checked="" type="checkbox"/>			Continuity	101333008	Other	N/A

Circuit Tests												
Circuit number and line	Circuit impedances					Insulation resistance				Polarity	RCD	
	Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)		Line/Line	Line/Neutral	Line/Earth	Earth/Neutral		Operating times	
	r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	R ₁ + R ₂	R ₂	MΩ	MΩ	MΩ	MΩ		At I _{Δn}	At 5I _{Δn}
											ms	ms
9/L1	-	-	-	-	-	-	-	-	-	-	-	
9/L2	-	-	-	-	-	-	-	-	-	-	-	
9/L3	-	-	-	-	-	-	-	-	-	-	-	
10/L1	-	-	-	-	-	-	-	-	-	-	-	
10/L2	-	-	-	-	-	-	-	-	-	-	-	
10/L3	-	-	-	-	-	-	-	-	-	-	-	
11/L1	-	-	-	-	-	-	-	-	-	-	-	
11/L2	-	-	-	-	-	-	-	-	-	-	-	
11/L3	-	-	-	-	-	-	-	-	-	-	-	
12/L1	-	-	-	-	-	-	-	-	-	-	-	
12/L2	-	-	-	-	-	-	-	-	-	-	-	
12/L3	-	-	-	-	-	-	-	-	-	-	-	
13/L1	-	-	-	-	-	-	-	-	-	-	-	
13/L2	-	-	-	-	-	-	-	-	-	-	-	
13/L3	-	-	-	-	-	-	-	-	-	-	-	
14/L1	-	-	-	-	-	-	-	-	-	-	-	
14/L2	-	-	-	-	-	-	-	-	-	-	-	
14/L3	-	-	-	-	-	-	-	-	-	-	-	
15/TP	-	-	-	-	-	-	-	-	-	-	-	
16/L1	-	-	-	-	-	-	-	-	-	-	-	
16/L2	-	-	-	-	-	-	-	-	-	-	-	
16/L3	-	-	-	-	-	-	-	-	-	-	-	

Tested By												
Signature					Position	Electrician						
Name	Brian Stanford				Date of testing	09/05/2019						

Board Details

TO BE COMPLETED IN EVERY CASE		ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION							
Location of distribution board	GROUND FLOOR ELECTRICAL RISER	Supply to distribution board is from	SubMains(RISING BUSBAR, 2/TP)					Associated RCD (if any)	
Distribution board designation	DB/G/L	No of phases	3	Nominal Voltage	400	V	BS(EN) N/A	RCD No of poles	N/A
		Overcurrent protective device for the distribution circuit					Rating 100 A	RCD rating, $I_{\Delta n}$	N/A mA
		Type BS(EN)	60947-2 MCCB						

Circuit Details

Circuit number and line	Circuit designation	Type of wiring	Reference method	No of points served	Circuit conductors csa		Max. permitted disconnection time s	Overcurrent protective device				RCD	Max. permitted Zs
					Live mm ²	cpc mm ²		BS(EN)	Type	Rating A	Short circuit capacity kA		
1/L1	LIGHTING LCM SPUR	O	E	4	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	2.19
1/L2	LIGHTING LCM SPUR	O	E	4	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	2.19
1/L3	LIGHTING HARDWIRED LCM ZONE 2	O	E	49	2.5	2.5	0.4	60898 MCB	B	10	10	N/A	4.37
2/L1	LIGHTING HARDWIRED LCM ZONE 3	O	E	26	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	2.19
2/L2	LIGHTING LCM SPUR	O	E	1	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	2.19
2/L3	LIGHTING HARDWIRED LCM ZONE 4	O	E	14	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	2.19
3/L1	LIGHTING AREA CONTROLLER	O	E	1	2.5	2.5	0.4	60898 MCB	C	10	10	N/A	2.19
3/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
3/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
4/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
4/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
4/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
5/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
5/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
5/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
6/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
6/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
6/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-

Wiring Code

A	B	C	D	E	F	G	H	O
Thermoplastic insulated/sheathed cables	Thermoplastic cables in metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic/SWA cables	Thermosetting/SWA cables	Mineral-insulated cables	Other

Board Tests											
ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION								TEST INSTRUMENTS (SERIAL NUMBERS) USED			
Z _s	0.03	Ω	Operating times of associated RCD (if any)	At I _{Δn}	N/A	ms	Earth fault loop impedance	101333008	RCD	101333008	
I _{pf}	9.1	kA		At 5I _{Δn} (if applicable)	N/A	ms	Insulation resistance	101333008	Multi-function	N/A	
Confirmation of Supply polarity	<input checked="" type="checkbox"/>	Phase sequence confirmed (where appropriate)		<input checked="" type="checkbox"/>			Continuity	101333008	Other	N/A	

Circuit Tests														
Circuit number and line	Circuit impedances					Insulation resistance				Polarity	RCD			
	Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)		Line/ Line	Line/ Neutral	Line/ Earth	Earth/ Neutral		Operating times			
	r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	R ₁ + R ₂	R ₂						At I _{Δn}	At 5I _{Δn}		
	MΩ	MΩ	MΩ	MΩ	Ω						ms	ms		
1/L1	N/A	N/A	N/A	0.26	N/A	N/A	>299	>299	>299	✓	0.38	N/A	N/A	N/A
1/L2	N/A	N/A	N/A	0.36	N/A	N/A	>299	>299	>299	✓	0.48	N/A	N/A	N/A
1/L3	N/A	N/A	N/A	2.94	N/A	N/A	>299	>299	>299	✓	3.06	N/A	N/A	N/A
2/L1	N/A	N/A	N/A	1.70	N/A	N/A	>299	>299	>299	✓	1.82	N/A	N/A	N/A
2/L2	N/A	N/A	N/A	0.37	N/A	N/A	>299	>299	>299	✓	0.49	N/A	N/A	N/A
2/L3	N/A	N/A	N/A	0.63	N/A	N/A	>299	>299	>299	✓	0.75	N/A	N/A	N/A
3/L1	N/A	N/A	N/A	0.01	N/A	N/A	>299	>299	>299	✓	0.13	N/A	N/A	N/A
3/L2	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3/L3	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4/L1	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4/L2	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4/L3	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5/L1	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5/L2	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5/L3	-	-	-	-	-	-	-	-	-	-	-	-	-	-
6/L1	-	-	-	-	-	-	-	-	-	-	-	-	-	-
6/L2	-	-	-	-	-	-	-	-	-	-	-	-	-	-
6/L3	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By					
Signature	Brian Stanford	Position	Electrician		
Name	Brian Stanford	Date of testing	29/04/2019		

SCHEDULE OF CIRCUIT DETAILS FOR THE INSTALLATION

ICN0000146 - Master

Board Details

TO BE COMPLETED IN EVERY CASE		ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION					
Location of distribution board	GROUND FLOOR ELECTRICAL RISER	Supply to distribution board is from	SubMains(RISING BUSBAR, 2/TP)				Associated RCD (if any)
Distribution board designation	DB/G/P	No of phases	3	Nominal Voltage	400	V	BS(EN) N/A
		Overcurrent protective device for the distribution circuit				RCD No of poles	N/A
		Type BS(EN)	60947-2 MCCB	Rating	100	A	RCD rating, $I_{\Delta n}$ mA
							N/A mA

Circuit Details

Circuit number and line	Circuit designation	Type of wiring	Reference method	No of points served	Circuit conductors csa		Max. permitted disconnection time s	Overcurrent protective device				Max. permitted Zs
					Live mm ²	cpc mm ²		BS(EN)	Type	Rating A	Short circuit capacity kA	
1/L1	FLOOR TRACK 4	G	C	1	10	10	0.4	60898 MCB	C	32	10	N/A 0.68
1/L2	FLOOR TRACK 1	G	C	1	10	10	0.4	60898 MCB	C	32	10	N/A 0.68
1/L3	FLOOR TRACK 2	G	C	1	10	10	0.4	60898 MCB	C	32	10	N/A 0.68
2/L1	FLOOR TRACK 5	G	C	1	10	10	0.4	60898 MCB	C	32	10	N/A 0.68
2/L2	FLOOR TRACK 3	G	C	1	10	10	0.4	60898 MCB	C	32	10	N/A 0.68
2/L3	GENERAL USE SOCKETS 1	G	C	20	4	4	0.4	61009 RCD/RCBO	C	32	10	30 0.68
3/L1	GENERAL USE SOCKETS 2	G	C	8	4	4	0.4	61009 RCD/RCBO	C	32	10	30 0.68
3/L2	PHONE BOOTH - RADIAL	G	C	1	4	4	0.4	61009 RCD/RCBO	C	20	10	30 1.09
3/L3	AV SOCKETS	G	C	6	4	4	0.4	61009 RCD/RCBO	C	32	10	30 0.68
4/L1	DISHWASHER BACK OF HOUSE	G	C	1	4	4	0.4	61009 RCD/RCBO	C	32	10	30 0.68
4/L2	AV SOCKETS	G	C	2	4	4	0.4	61009 RCD/RCBO	C	20	10	30 1.09
4/L3	GENERAL USE SOCKETS 3	G	C	3	4	4	0.4	61009 RCD/RCBO	C	32	10	30 0.68
5/L1	TEA POINT RING	G	C	7	4	4	0.4	61009 RCD/RCBO	C	32	10	30 0.68
5/L2	AV SOCKETS	G	C	5	4	4	0.4	61009 RCD/RCBO	C	20	10	30 1.09
5/L3	FAN COIL RING	O	E	8	4	4	0.4	60898 MCB	C	32	10	N/A 0.68
6/L1	ZIP TAP BACK OF HOUSE	G	C	1	4	4	0.4	60898 MCB	C	16	10	N/A 1.37
6/L2	PSU MAG LOCKS	O	C	1	4	4	0.4	60898 MCB	C	16	10	N/A 1.37
6/L3	FAN COIL RING	O	E	7	4	4	0.4	60898 MCB	C	16	10	N/A 1.37
7/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-
7/L2	CLEANERS SOCKETS	G	C	6	4	4	0.4	61009 RCD/RCBO	C	32	10	30 0.68
7/L3	COFFEE BAR RING	G	C		4	4	0.4	61009 RCD/RCBO	C	32	10	30 0.68
8/L1	RECEPTION SOCKETS	G	C	1	4	4	0.4	61009 RCD/RCBO	C	20	10	30 1.09
8/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-
8/L3	COFFEE BAR BOILER	G	C	1	4	4	0.4	60898 MCB	C	16	10	N/A 1.37

Wiring Code

A	B	C	D	E	F	G	H	O
Thermoplastic insulated/ sheathed cables	Thermoplastic cables in metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic SWA cables	Thermosetting/ SWA cables	Mineral-insulated cables	Other

Board Tests														
ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION								TEST INSTRUMENTS (SERIAL NUMBERS) USED						
Z _s	0.03	Ω	Operating times of associated RCD (if any)	At I _{Δn}	N/A	ms	Earth fault loop impedance	101333008	RCD	101333008				
I _{pf}	9.1	kA		At 5I _{Δn} (if applicable)	N/A	ms	Insulation resistance	101333008	Multi-function	N/A				
Confirmation of Supply polarity	<input checked="" type="checkbox"/>	Phase sequence confirmed (where appropriate)		<input checked="" type="checkbox"/>			Continuity	101333008	Other	N/A				
Circuit Tests														
Circuit number and line	Circuit impedances				Insulation resistance				Polarity	RCD				
	Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)	Line/ Line	Line/ Neutral	Line/ Earth	Earth/ Neutral		Operating times				
	r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	R ₁ + R ₂						R ₂	MΩ	MΩ	MΩ	At I _{Δn}
								Ω	ms	ms	Test button operation			
1/L1	N/A	N/A	N/A	0.04	N/A	N/A	>299	>299	>299	✓	0.16	N/A	N/A	N/A
1/L2	N/A	N/A	N/A	0.03	N/A	N/A	>299	>299	>299	✓	0.15	N/A	N/A	N/A
1/L3	N/A	N/A	N/A	0.04	N/A	N/A	>299	>299	>299	✓	0.16	N/A	N/A	N/A
2/L1	N/A	N/A	N/A	0.03	N/A	N/A	>299	>299	>299	✓	0.15	N/A	N/A	N/A
2/L2	N/A	N/A	N/A	0.03	N/A	N/A	>299	>299	>299	✓	0.15	N/A	N/A	N/A
2/L3	0.85	0.85	0.18	0.12	N/A	N/A	>299	>299	>299	✓	0.29	29	29	✓
3/L1	0.76	0.72	0.12	0.07	N/A	N/A	>299	>299	>299	✓	0.33	28.4	28.9	✓
3/L2	N/A	N/A	N/A	0.33	N/A	N/A	>299	>299	>299	✓	0.45	29	29.1	✓
3/L3	0.45	0.45	0.26	0.15	N/A	N/A	>299	>299	>299	✓	0.19	29	28.8	✓
4/L1	0.09	0.09	0.04	0.02	N/A	N/A	>299	>299	>299	✓	0.11	28.9	28.9	✓
4/L2	N/A	N/A	N/A	0.30	N/A	N/A	>299	>299	>299	✓	0.42	29	28.8	✓
4/L3	N/A	N/A	N/A	0.19	N/A	N/A	>299	>299	>299	✓	0.11	28.9	29	✓
5/L1	0.26	0.26	0.09	0.04	N/A	N/A	>299	>299	>299	✓	0.22	38.9	28.8	✓
5/L2	N/A	N/A	N/A	0.26	N/A	N/A	>299	>299	>299	✓	0.36	38.9	28.9	✓
5/L3	0.59	0.59	0.12	0.15	N/A	N/A	>299	>299	>299	✓	0.25	N/A	N/A	N/A
6/L1	N/A	N/A	N/A	0.11	N/A	N/A	>299	>299	>299	✓	0.23	N/A	N/A	N/A
6/L2	N/A	N/A	N/A	0.05	N/A	N/A	>299	>299	>299	✓	0.17	N/A	N/A	N/A
6/L3	0.55	0.56	0.15	0.17	N/A	N/A	>299	>299	>299	✓	0.20	N/A	N/A	N/A
7/L1	-	-	-	-	-	-	-	-	-	-	-	-	-	-
7/L2	0.78	0.77	0.18	0.12	N/A	N/A	>299	>299	>299	✓	0.30	38.8	28.9	✓
7/L3	0.28	0.28	0.15	0.07	N/A	N/A	>299	>299	>299	✓	0.16	28.9	28.9	✓
8/L1	N/A	N/A	N/A	0.12	N/A	N/A	>299	>299	>299	✓	0.24	29	29	✓
8/L2	-	-	-	-	-	-	-	-	-	-	-	-	-	
8/L3	N/A	N/A	N/A	0.18	N/A	N/A	>299	>299	>299	✓	0.30	N/A	N/A	N/A

Tested By

Signature	Brian Stanford	Position	Electrician
Name	Brian Stanford	Date of testing	29/04/2019

S . L . E . S

Specialist Lightning & Earthing Services

PASS

CERTIFICATE OF TEST

Client:	Buxton Electrical		
Site:	22 Tudor Street, London, EC4Y 0AY		
Structure Tested:	22 Tudor Street, London, EC4Y 0AY		
Test Date:	April 2019	Issue Date:	April 2019
Air Termination:	25x 3 mm PVC Coated Aluminium Conductor		
Down Conductor:	Structural Steel Frame		
Project No.:	01975	Test Engineer:	D.Anderson
Test Method:	Two Pole	Building Height:	20m

We certify that the lightning protection system installed at the above site has been tested and visually inspected in accordance with BS 6651:1999 , BS EN 62305:2011 , BS 7430:2011 and BS 7671:2008 IET Wiring Regulations (17th Edition).

In accordance with the 17th Edition Regulations, the lightning protection system requires a test and visual inspection to be carried out at intervals not exceeding 12 months. Additionally, electrical testing of the system has been carried out in accordance with the requirements of the aforementioned Standard guidelines.

Roof Level Continuity Tests

	Continuity Reading		Continuity Reading		Continuity Reading		Continuity Reading
Position 1	0.71 Ω	Position 2	0.62Ω	Position 3	0.71 Ω	Position 4	0.60 Ω
Position 5	0.67 Ω	Position 6	0.72Ω	Position 7	0.77 Ω	Position 8	0.80 Ω
Combined Value:	0.55 Ω			Next Test & Inspection Due:		April 2020	

Test Instrument:	4105A	Model:	Kyoritsu
Calibration No.:	CAP090118/02	Calibration Expiry Date:	June 2019
Signed:	<i>Arran Anderson</i>	Name:	Mr Arran Anderson

Standards:	This record shows that this installation does generally comply with the edition of BS 6651 (installation design criteria) at the time of this Test.
-------------------	---